

Article

A Novel Algorithm for Optimal Operation of Hydrothermal Power Systems under Considering the Constraints in Transmission Networks

Thang Trung Nguyen ¹, Bach Hoang Dinh ², Nguyen Vu Quynh ³, Minh Quan Duong ⁴, and Le Van Dai ^{5,6,*}

- ¹ Power System Optimization Research Group, Faculty of Electrical and Electronics Engineering, Ton Duc Thang University, Ho Chi Minh City 700000, Vietnam; nguyentrungthang@tdt.edu.vn
- ² Faculty of Electrical and Electronics Engineering, Ton Duc Thang University, Ho Chi Minh City 700000, Vietnam; dinhhoangbach@tdt.edu.vn
- ³ Department of Electrical Engineering, Lac Hong University, Bien Hoa 810000, Vietnam; vuquynh@lhu.edu.vn
- ⁴ Department of Electrical Engineering, The University of Da Nang—University of Science and Technology, Danang 550000, Vietnam; dmquan@dut.udn.vn
- ⁵ Institute of Research and Development, Duy Tan University, Danang 550000, Vietnam
- ⁶ Office of Science Research and Development, Lac Hong University, Bien Hoa 810000, Vietnam
- * Correspondence: levandai@duytan.edu.vn; Tel.: +84-901-672-689

Received: 29 November 2017; Accepted: 8 January 2018; Published: 12 January 2018

Abstract: This paper proposes an effective novel cuckoo search algorithm (ENCSA) in order to enhance the operation capacity of hydrothermal power systems, considering the constraints in the transmission network, and especially to overcome optimal power flow (OPF) problems. This proposed algorithm is developed on the basis of the conventional cuckoo search algorithm (CSA) by two modified techniques: the first is the self-adaptive technique for generating the second new solutions via discovery of alien eggs, and the second is the high-quality solutions based on a selection technique to keep the best solutions among all new and old solutions. These techniques are able to expand the search zone to overcome the local optimum trap and are able to improve the optimal solution quality and convergence speed as well. Therefore, the proposed method has significant impacts on the searching performances. The efficacy of the proposed method is investigated and verified using IEEE 30 and 118 buses systems via numerical simulation. The obtained results are compared with the conventional cuckoo search algorithm (CCSA) and the modified cuckoo search algorithm (MCSA). As a result, the proposed method can overcome the OPF of hydrothermal power systems better than the conventional ones in terms of the optimal solution quality, convergence speed, and high success rate.

Keywords: cuckoo search algorithm (CSA); constraints in a transmission network; hydrothermal power systems; optimal power flow

1. Introduction

Optimal power flow (OPF) is a complex problem for the operation of a power system due to its dependence on many equality and inequality constraints, such as the limit of active and reactive powers of electric generators, transformer tap positions, switchable capacitor banks, bus-voltage values, and capacity of lines transmission [1]. The purpose of the OPF problem is to determine the values of control variables and how to carry out an OPF in order to obtain all dependent variables. A solution is considered an optimal result if it gives the minimum fuel cost for all thermal units while satisfying all dependent variables and constraints. Normally, the OPF problem is only run for one sub-interval.



The hydrothermal scheduling (HTS) problem is relatively different from the OPF problem since the thermal and hydro units are included in power systems. The target of the HTS problem is to minimize the fuel cost of the thermal units in various scheduled sub-intervals while satisfying all constraints in the generators' capacities, the balance of power systems, as well as limitations of water discharge, water balance, etc. In addition, the optimal operation of hydrothermal systems is divided into many sub-intervals, which is more complicated than a single sub-interval in the OPF problem. Apparently, the OPF problem considers all constraints in transmission lines, but hydraulic constraints from hydropower plants are neglected.

Practically, so far the HTS and OPF problems have been studied independently. For instance, the HTS problem was discussed in [1-12] and the OPF problem was presented in [13-47]. However, combining the OPF and HTS problems was attempted by the authors in [48–54]; but they only use methods belonging to the deterministic algorithms [48–53] applied in the past three decades. In order to solve this combined problem, Newton's is the first method applied, where IEEE systems from 5 to 118 buses accompanied by a fixed-head short-term hydropower plant model are tested. The study objective is only to indicate the ability of the Newton approach to deal with the complicated problem and to satisfy all constraints such as the voltage, generation limitations on units, as well as other constraints in transmission lines. The whole data of the test systems was not given in these papers and the objective function values were not considered for comparisons. The two difficulties have restricted to attract attention from researchers, leading to a small number of published papers regarding the problem. In [49-52], the authors only considered the transmission network constraints when dealing with the hydrothermal system scheduling problem. They have built and solved their own problem data and their applied method could handle the problem. On the contrary, in [53], the authors have proposed an improved particle swarm optimization (PSO) algorithm to solve the eight-bus system; as in previous studies, the improved PSO is used in order to obtain the optimal solution for the HTS problem while satisfying the constraints of the OPF problem. The authors of [54] have developed a conventional cuckoo search algorithm (CCSA) for solving the hydrothermal optimal power flow problem (HTOPF) and the performance of the conventional CSA was also compared via conventional PSO. They supposed that the capacitor bank and tap changer were the continuous variables and the load demands between different subintervals were identical to the given data in the OPF problem. This assumption could help verify the effectiveness and robustness of conventional CSA compared to the conventional PSO. However, the capacitors and tap should be the discrete variables in practice and the load demands of different subintervals should be different. Consequently, in order to solve the hydrothermal OPF problem, this paper proposes an effective novel cuckoo search algorithm (ENCSA) for optimizing the operation of hydrothermal power systems, taking into account all constraints belonging to the transmission power networks and considering the minimization of electricity and fuel costs as the objective function. The procedure for searching CCSA [55] is constructed of five main steps: step 1, the first update of new solutions via the theory of Lévy flights; step 2, comparison and selection; step 3, the second update of new solutions via a mutation operation; step 4, comparison and selection; and step 5, the determination of the best solution. Modified CSA (MCSA) [56] has focused on the improvement in the first update of new solutions using Lévy flights, while the next four steps have remained unchanged in MCSA. This MCSA has divided all current solutions into two subgroups by quality, in which the first one contains lower fitness function solutions and the second one contains higher fitness function solutions. Each solution in the first subgroup is newly produced by using its old solution and two other ones in the group, while each solution in the second subgroup is newly updated as in step 1 of CCSA, i.e., using an old solution and the best solution. In addition, MCSA has suggested an adaptive value for the scaling factor, with the change depending on the iteration. In ENCSA, we focus on improvement of steps 3 and 4, corresponding to the second update of new solutions and the comparison and selection. In the second update of new solutions, we propose an adaptive mutation technique by using two mutation modes simultaneously for current solutions. Solutions far away from the so-far best solution will use a jumping step with two random

solutions and they are newly updated. On the contrary, solutions close to the so-far best solution will use four random solutions to produce a jumping step and solutions are sought around the so-far best solution instead of around the current solution. In step 4, CCSA makes a comparison between each old solution and each new solution at the same nest and keeps the better one. The selection can cope with a mistake (i.e., a better solution at one nest can be worse in quality than another one at other ones). For this case, CCSA omitted promising solutions. Thus, we have tackled the cons of CCSA by suggesting a second modification: firstly, all old solutions and all new solutions are mixed together; secondly, identical solutions are identified, and only one solution is retained, while others are eliminated; finally, a set of the best solutions is stored for the next step of determining the best solution. To investigate the improvement of ENCSA over CCSA and MCSA, we perform simulation experiments on IEEE 30 and 118 buses systems. The obtained results are analyzed and compared to those from CCSA and MCSA. More concretely, the main contribution includes the following aspects:

- (i) Successfully improve the optimal solution search ability of ENCSA;
- (ii) Successfully formulate a hydrothermal power system scheduling problem considering all constraints in transmission power networks;
- (iii) Successfully deal with all constraints such that they can be satisfied completely thanks to the appropriate selection of decision variables.

This paper is divided into one appendix and six sections. Starting with an introduction in Section 1, Section 2 covers the formulation of the hydrothermal optimal power flow problem while Section 3 gives the proposed algorithm for optimal power flow problem of the hydrothermal power systems. Section 4 presents an application of the proposed method to deal with the optimal power flow problems, while simulation results are handled in Section 5 and Appendix A. Finally, conclusions are reported in Section 6.

2. Hydrothermal Optimal Power Flow Problem Formulation

The main formulation for dealing with the optimal power flow problems of hydrothermal power systems is as follows.

2.1. Fuel Cost Objective

The objective optimization of the considered problem is to reduce the total electricity generation and fuel costs of all available generating units as [3]:

$$\operatorname{Min}\sum_{i=1}^{N_g} F_i(P_{gi}),\tag{1}$$

where $F_i(P_{gi})$ is the electricity generation cost of the *i*th generating thermal unit and can be described by the following second-order equation:

$$F_i(P_{gi}) = a_i + b_i P_{gi} + c_i P_{gi}^2.$$
 (2)

2.2. Hydrothermal System Constraints

Water availability constraints can be described as follows [4]:

$$\sum_{m=1}^{M} t_m q_{j,m} = W_j; \quad j = 1, \dots, N_2,$$
(3)

where $q_{i,m}$ is the water discharge via hydro turbine *j* in subinterval *m* and can be calculated by:

$$q_{j,m} = a_{hj} + b_{hj}P_{hj,m} + c_j P_{hj,m}^2.$$
(4)

Generator Operating Limits: The active and reactive powers of thermal and hydro units are constrained between their minimum and maximum values as follows:

$$P_{gi,\min} \le P_{gi} \le P_{gi,\max}; i = 1, \dots, N_g,$$

$$Q_{gi,\min} \le Q_{gi} \le Q_{gi,\max}; i = 1, \dots, N_g$$
(5)

Generation bus voltage limits: The operating voltage of all generators is constrained within their boundaries:

$$V_{gi,\min} \le V_{gi} \le V_{gi,\max}; i = 1, \dots, N_g.$$
(6)

2.3. Transmission Network Constraints

Power balance: The active and reactive power balance between the load and generator at each bus is considered [13]:

$$P_{gi} - P_{di} = V_i \sum_{j=1}^{N_b} V_j [G_{ij} \cos(\delta_i - \delta_j) + B_{ij} \sin(\delta_i - \delta_j)]; \ i = 1, \dots, N_b,$$

$$Q_{gi} + Q_{ci} - Q_{di} = V_i \sum_{j=1}^{N_b} V_j [G_{ij} \sin(\delta_i - \delta_j) - B_{ij} \cos(\delta_i - \delta_j)]; \ i = 1, \dots, N_b$$
(7)

Minimum and maximum limits of shunt compensators: The reactive power generated for the grid by capacitor banks must be within the following limitations:

$$Q_{ci,\min} \le Q_{ci} \le Q_{ci,\max}; i = 1, \dots, N_c.$$
(8)

Practically, the reactive power generated for the grid by the capacitor banks is not a continuous variable but a discrete variable. Therefore, the exact value of the capacitor banks should follow the equation [46]:

$$Q_{ci} = Q_{ci,\min} + N_{ci} \cdot \Delta Q_{ci},\tag{9}$$

where ΔQ_{ci} is the rated power of each capacitor and N_{ci} is the selected number of capacitors among the set of available capacitors. However, in some cases, the number of available capacitors and the rated power are not given and only the minimum and the maximum values are given; the value Q_{ci} is newly generated within its boundaries and then is rounded up or down to the nearest unit.

Limits of transformer tap selection: The selection of transformer taps with aim to stabilize power network voltage but it should be one of a set of specific values of each available transformer at buses by the model below:

$$T_{k,\min} \le T_k \le T_{k,\max}; \ k = 1, \dots, N_t.$$

$$(10)$$

Similar to the capacitor banks variable, the magnitude of the load tap changer is also not a continuous variable but a discrete variable since the tap is changing by a certain increment. This increment is also dependent on the size of the specified transformer, as in the following equation [46]:

$$T_k = T_{k,\min} + N_{tk} \cdot \Delta T_k. \tag{11}$$

Limitations of voltage at load buses: The operating voltage of each load must be within valid range and can be described as follows:

$$V_{li,\min} \le V_{li} \le V_{li,\max}; i = 1, \dots, N_d.$$

$$(12)$$

Limitations of transmission lines: The apparent power flow in each line must be lower than the allowable capacity of conductor, and can be calculated as follows:

$$S_l \le S_{l,\max}; \ l = 1, \dots, N_l, \tag{13}$$

where $S_l = \max\{|S_{ij}|, |S_{ji}|\}.$

2.4. Control and Dependent Variables

The sets of control and dependent variables of the HTOPF problem are shown in Equations (14) and (15). It is clear that the control variables consist of active power of all generators at all buses except at the slack bus, the voltage of all generators, the transformer tap, and the reactive power of shunt capacitors. The control variables will be added into the program of power flow and then we will obtain the dependent variables given in Equation (15). When all dependent variables can satisfy their boundaries and the objective function can be minimized, the search process is terminated.

$$u = \left\{ P_{g2}, \ldots, P_{gN_g}, V_{g1}, \ldots, V_{gN_g}, T_1, \ldots, T_{N_t}, Q_{c1}, \ldots, Q_{cN_c} \right\}^T,$$
(14)

$$x = \left\{ P_{g1}, Q_{g1}, \dots, Q_{gN_g}, V_{l1}, \dots, V_{lN_d}, S_{l1}, \dots, S_{lN_l} \right\}^T.$$
(15)

3. The Proposed Algorithm for the Optimal Power Flow Problem of the Hydrothermal Power Systems

This paper develops an improved version of CCSA by carrying out modifications on two existing techniques of CCSA. For the sake of simplicity, the construction of the CCSA is first described in detail as follows.

3.1. Conventional Cuckoo Search Algorithm

The CCSA method is constructed of two random walks and one selection operation. The three phases can be described as follows.

Lévy flights random walk: CCSA utilizes the random walk technique based on the behavior of Lévy flight to produce the first update of new solutions to its search procedure. For solution d, its new solution X_d^{new} is updated by using a jumping step to a nearby old solution X_d . The jumping step is created using the so-far best solution G_{best} , old solution X_d and Lévy flights random walk, as seen in Equation (16):

$$X_d^{new} = X_d + \alpha_0 (X_d - G_{best}) \text{Lévy}(\beta).$$
(16)

Selective random walk: The selective random walk also plays a role similar to the mutation operation of DE to perform the second update of new solutions for CCSA. A probability of solution replacement P_{ro} with the range of [0, 1] is selected to balance the old and new solutions effectively. The selective random walk can be employed as in the following model:

$$X_d^{new} = \begin{cases} X_d + rand.(X_{randper1} - X_{ranper2}) & if \ rand_d < P_{ro} \\ X_d & otherwise \end{cases}$$
(17)

Selection Operation: CCSA utilizes selection operation to perform a comparison between each old solution and each new solution at each nest and retain more promising solutions to avoid accepting worse quality solutions. The selection is based on fitness comparison, as seen in Equation (18):

$$X_{d} = \begin{cases} X_{d}^{new} & if \ Fitness \ (X_{d}^{new}) < \ Fitness(X_{d}) \\ X_{d} & otherwise \end{cases}, \ d = 1, \dots, N_{p}.$$
(18)

The model in Equation (18) is applied twice: first after Lévy flights random walk, and a second time after selected random walk. However, the task of determining the best solution G_{best} is carried out

only one time at each iteration because the best solution will be used in Equation (16) at the beginning of each iteration.

3.2. Proposed Cuckoo Search Algorithm

As described in Section 3.1, CCSA is comprised of three stages including two new solution generations via Lévy flights and discovery of alien eggs, and selection operation. Between the two ways for searching new solutions, the Lévy flight technique focuses on global search while discovery of alien eggs aims to exploit a local search. Moreover, selection operation will be carried out to retain a set of so-far dominant solutions. However, the results obtained from applications of the CCSA to different optimization problems in different fields have indicated that the method has many weak points such as lower-quality solutions, a slow convergence speed, and a high number of iterations. In this paper, an effective novel cuckoo search algorithm (ENCSA) is introduced to tackle the drawbacks of CCSA by constructing two modifications on CCSA. The first modification aims to determine a feasible local search zone for each solution via the discovery of alien eggs while the second modification on selection operation will enable ENCSA to select the potential solutions. The details of the improvements are as follows.

The proposed self-adaptive technique for the second update of new solutions: In the second update of new solutions via selective random walk, CCSA employs two arbitrary solutions to produce a jumping step away from the old solutions for updating a new solution, as shown in Equation (17). However, the impact of this step will be smaller and narrower since the distribution of solutions tends to be close together and the zone near the best solution is ignored when the search process goes to higher iterations. Furthermore, the last iterations are the improvement of solutions near the current best solution because these solutions tend to update their position near the best solution, while searching around the best solution is performed only one time, as the old solution is also the best solution. This issue can lead to a local optimum and low convergence to the highest optimal solution. The restrictions of CCSA can be overcome by employing the search strategy included in Equations (19) and (20):

$$X_d^{new} = X_d + rand.(X_{randper1} - X_{ranper2}),$$
⁽¹⁹⁾

$$X_d^{new} = Gbest + rand.(X_{randper1} - X_{ranper2} + X_{randper3} - X_{ranper4}).$$
⁽²⁰⁾

Obviously, the search methods using the models in Equations (19) and (20) are completely different because the method of Equation (19) is to exploit a small zone around individuals while the aim of applying Equation (20) is to reach the zone around the best solution. Thus, using Equation (20) can produce a jump large enough in the search zone to avoid a local optimum and a fall into a zone very close to the so-far best solution G_{best} or even at the same position of the best solution. For a better understanding, the assumptions are illustrated in Figure 1, in which X_{old2} is much closer to G_{best} than X_{old1} , and thus Equation (19) is more appropriate for X_{old1} and Equation (20) is better for the case of X_{old2} . Consequently, using such two models simultaneously for the most effective impact is important to determine an exact criterion. The criterion of small or high distance can be measured mathematically using the fitness function value of each individual and of the best solution, as shown in the model below:

$$D_d = \frac{Fitness_d - Fitness_{best}}{Fitness_{best}}.$$
(21)

Equations (19) or (20) compare D_d and a predetermined tolerance (*tol*). If D_d is higher than *tol*, it means the current solution *d* is far from the best one; Equation (19) should be used. Otherwise, if D_d is equal to or lower than *tol*, it means the current solution *d* is closer to the best solution; Equation (20) should be used instead. In the demonstration of this paper, *tol* is the tolerance picked from one value in the range of $[10^{-5}-10^{-1}]$. The procedure for the self-adaptive technique for the second update of new solutions via the discovery action of alien eggs is proposed in Table 1.



Figure 1. Two ways for updating the second new solution generation.

Table 1. Self-adaptive technique for the second update of new solutions.

```
 \begin{array}{c} \text{if } \textit{rand}_d < P_{ro} \\ Calculate \ D_d \\ \text{if } D_d > \textit{tol} \\ X_d^{new} = X_d + \textit{rand}.(X_{\textit{randper1}} - X_{\textit{ranper2}}) \\ \text{else} \\ X_d^{new} = \textit{Gbest} + \textit{rand}.(X_{\textit{randper1}} - X_{\textit{ranper2}} + X_{\textit{randper3}} - X_{\textit{ranper4}}) \\ \text{end} \\ \text{else} \\ X_d^{new} = X_d \\ \text{end} \\ \end{array}
```

The top solutions-based selection technique: As shown in Equation (18), after generating new solutions in the population, at each nest the old solution and its new solution are compared to keep the one with the better fitness function and eliminate the worse one. However, there is no guarantee that all new solutions meet the constraints of the application, thus a retained solution is possibly not the better of the two compared solutions. Additionally, there is a possibility that an abandoned solution at a nest is better than a retained solution at another nest and the selection technique of CCSA could miss some promising solutions to reach the global optimization faster because the current population is not a set of the best candidates. To enhance the alternative technique of CCSA, we propose a new alternative mechanism called the alternative technique-based dominant solution. It is described in Table 2.

Table 2. The top solutions-based selection technique.

```
Step 1. Mix all old solutions and all new solutions
```

Step 2. Identify identical solutions. Keep only one and eliminate rest of identical ones

Step 3. Sort all solutions in order of ascending fitness function values

Step 4. Keep the first N_p solutions

Applying the proposed high-quality selection technique can retain the best different solutions with lower fitness function and can eliminate worse solutions. In other words, it can keep a set of the best candidates in the population. Therefore, it can support the proposed method converges to global optimal solutions fast and increases the probability of finding solutions meeting all constraints, leading to a high success rate for a number of trial runs.

4. Application of the Proposed Method to Deal with the Optimal Power Flow Problems

4.1. Initialization

There are nests N_p in the population of the proposed method and each nest d will contain almost all the control variables in Equation (13). The chosen element in each nest plays a very important role in handling all constraints from hydropower plant reservoirs and transmission lines. Each nest includes all control variables in Equation (13) for M - 1 subintervals, while the output power of all hydropower plants is not included for the last subinterval M. The variables in each nest and the initialization for each nest are as follows:

$$X_{d,m} = [P_{g2}, \ldots, P_{gN_g}, V_{g1}, \ldots, V_{gN_g}, Q_{c1}, \ldots, Q_{cN_c}, T_1, \ldots, T_{N_t}]; m = 1, \ldots, M - 1,$$
(22)

$$X_{d,m} = [P_{g2}, \ldots, P_{gN_1}, V_{g1}, \ldots, V_{gN_g}, Q_{c1}, \ldots, Q_{cN_c}, T_1, \ldots, T_{N_t}]; m = M,$$
(23)

$$X_{d,m} = X_{\min} + rand.(X_{\max} - X_{\min}); m = 1, 2, ..., M.$$
 (24)

4.2. Calculate the Remaining Control Variables for the Last Subinterval M

All control variables are available for the first M - 1 subintervals, as shown in Equation (22). However, all hydro generations are not given for the last subinterval. Certainly, running power flow will be done only for the first M - 1 subintervals. Consequently, the remaining control variables are found by calculating the water discharges for the first M - 1 subintervals $q_{j,m}$ (where $j = 1, ..., N_2$ and m = 1, ..., M - 1) for all hydropower plants by substituting generations into Equation (4); then using Equation (3), the water discharges for the last subinterval $Mq_{j,M}$ are obtained under the conditions of Equation (3), as follows:

$$q_{j,M} = (W_j - \sum_{m=1}^{M-1} t_m q_{j,m}) / t_M; \ j = 1, \dots, N_2.$$
(25)

As a result, all hydro generations during the last subinterval $P_{hj,M}$ are determined using Equation (4), as follows:

$$P_{hj,M} = \frac{-b_{hj} \pm \sqrt{b_{hj}^2 - 4c_{hj}(a_{hj} - q_{j,M})}}{2c_{hj}}.$$
(26)

4.3. Calculate Fitness Function

All the control variables are given and the power flow can be run for all *M* subintervals to obtain dependent variables, as shown in Equation (15). Then, it is necessary to calculate the fitness function for evaluating the solution quality. The fitness function of each solution is a sum of the total electricity generation fuel costs of all generators and the penalty terms for limitation violations of dependent variables. The following equation can enable the calculation of such a fitness function [54]:

$$FT = F_{1} + K_{1} \sum_{j=1}^{N_{2}} \left(P_{hjM} - P_{hjM}^{\lim} \right)^{2} + K_{2} \sum_{m=1}^{M} \left(P_{g1,m} - P_{g1,m}^{\lim} \right)^{2} + K_{3} \sum_{m=1}^{M} \sum_{i=1}^{N_{g}} \left(Q_{gi,m} - Q_{gi,m}^{\lim} \right)^{2} + K_{4} \sum_{m=1}^{M} \sum_{i=1}^{N_{d}} \left(V_{li} - V_{li}^{\lim} \right)^{2} + K_{5} \sum_{m=1}^{M} \sum_{l=1}^{N_{l}} \left(S_{l} - S_{l}^{\lim} \right)^{2}$$

$$(27)$$

where K_1 , K_2 , K_3 , K_4 , and K_5 are penalty factors associated with dependent variables.

Before going on to the search procedure of the proposed method, starting with the first update of new solutions, the best solution G_{best} with the lowest fitness function is determined.

4.4. Handling New Solutions Violating Limitations

Generate new solutions by using Lévy flights, as shown in Equation (16), and using the adaptive selective random walk technique, as shown in Section 3.2; after each generation, all new solutions do not always satisfy their limitations. Thus, they need to be checked and repaired in case of violation, as below:

$$X_{d,m}^{new} = \begin{cases} X^{max} & \text{if } X_{d,m}^{new} > X^{max} \\ X^{min} & \text{if } X_{d,m}^{new} < X^{min} & m = 1, \dots, M; \\ X_{d,m}^{new} & \text{otherwise} \end{cases}$$
(28)

4.5. Termination Criteria

The iterative algorithm will be stopped when the current iteration is equal to the predetermined maximum value.

4.6. The Effective Novel Cuckoo Search Algorithm for the Considered Problem

The entire search process of the proposed method to the considered problem is shown in Figure 2; below is the detailed explanation.



Figure 2. The flowchart of using the proposed method to solve the considered problem.

5. Simulation Results

The proposed method is tested on the IEEE 30 and 118 buses power systems. In addition, CCSA and MCSA are also implemented in these systems as a basis for comparison.

5.1. Selection of Control Parameters

In order to implement the proposed method, CCSA, and MCSA for solving the HTOPF problem, the update probability of new solutions ranges from 0.1 to 0.9 with a step of 0.1, where the tolerance (*tol*) for ENCSA is set to 10^{-3} . In addition, the number of nests and the maximum number of iterations for the applied methods are given in Table 3. For each study case, each method is run for 50 successful independent trials and the success rate (SR) is calculated by dividing the 50 successful independent runs by the total number of independent runs. The SR is also a comparison criterion to assess the handling constraints of the applied methods.

	System			
	30 Buses		118 Buses	
Method	Pa		arameter	
	Np	G _{max}	N_p	G _{max}
CCSA	10	150	20	300
MCSA	10	150	20	300
ENCSA	10	150	20	300

Table 3. Selection of control parameters for the applied algorithms.

5.2. Results Obtained from the IEEE 30 Buses System

The test system comprises 30 buses, among which are six-generation buses, 24-load buses, and 41 branches. The information on the 30 IEEE buses systems, thermal units and hydro units is taken from [54]. The optimal operation plan is carried out in 24 h, divided into two 12-h optimal subintervals. The load of the first subinterval is fixed at values of the IEEE 30 buses system but the load of the second is reduced to 85% of the first subinterval. The data on the hydro and thermal units are listed Tables A1 and A2, respectively.

The results obtained from three applied methods such as minimum, average, maximum, standard deviation, and execution time, in addition to the SR for obtaining 50 successful runs, are shown in Table 4. As observed from this table, that ENCSA has the lowest cost of \$13,655.538 while MCSA has the second best (\$13,718.230) and CCSA has the highest cost (\$13,722.208). The exact comparison indicates that ENCSA has a lower cost than CCSA and MCSA by \$66.67 and \$62.692, respectively. Furthermore, ENCSA is also superior in its handling constraints over CCSA and MCSA because its SR is approximately 100%, whereas that of CCSA and MCSA is 76% and 91%, respectively. The SR of ENCSA is higher than that of CCSA and MCSA by approximately 22% and 7%, respectively, due to the contribution of the proposed selection technique-based dominant solutions. This result proves the benefit of the proposed selection technique-based dominant solutions in ENCSA, keeping the best candidates among N_p old solutions and N_p new solutions, as explained in Section 3.2. Moreover, the optimal value (lowest fuel cost) of ENCSA is the best solution among the compared methods. According to the general compared indices, we can conclude that ENCSA is more efficient than CCSA and MCSA when applied to solve the IEEE 30 buses system because it is superior among the three methods in having the lowest cost (optimal solution quality) and the highest SR (ability to deal with constraints).

D (Method				
Parameter	CCSA	MCSA	ENCSA		
Pro	0.9	0.8	0.9		
Min. cost (\$)	13,722.208	13,718.230	13,655.538		
Mean cost (\$)	13,759.815	13,783.937	13,808.732		
Max. cost (\$)	13,815.143	14,066.094	14,548.909		
Std dev. (\$)	16.895	53.707	171.314		
CPU time (s)	67.036	65.695	65.871		
Successes rate (SR)	76%	91%	98%		

Table 4. Comparison of obtained results for the IEEE 30 buses system.

Figure 3 depicts the convergence characteristics of fitness functions of the three methods. As observed in this figure, at the iteration of 25 there is a distinction in the performance of the ENCSA over CCSA and MCSA. In fact, at beginning iterations ENCSA obtains higher fitness function values than both CCSA and MCSA, but later it decreases dramatically and from the iteration of 25 to the final iteration the fitness function of ENCSA is much less than that of CCSA and MCSA. Furthermore, the improvement of the fitness functions in CCSA and MCSA is slight from the 50th iteration onward. Thus, we can conclude that applying the self-adaptive technique in ENCSA enhances the research ability and avoids convergence to a local optimum, while CCSA and MCSA can be easily trapped into the local optimal.



Figure 3. Fitness function convergence characteristics for the IEEE 30 buses system.

Summarily, ENCSA is superior to CCSA and MCSA in terms of fast convergence to a global optimum and higher SR thanks to the contribution of the proposed self-adaptive technique as well as the selection technique-based dominant solutions.

5.3. Obtained Results of the IEEE 118 Buses System

In this section, the IEEE 118 buses system [48], considering hydraulic constraints from reservoirs, generation capacity constraints of generators, and constraints from transmission lines, is employed to demonstrate the applicability of the CSA methods for dealing with a very large-scale system. The schedule time horizon is 24 h, divided into two subintervals including a 20 h subinterval and a 4 h subinterval. The load demand in the first subinterval is from the base case of the system and

the load demand in the second is equal to 70% that of the first subinterval. The whole data of the IEEE 118 buses system is taken from [48] and other information on hydro and thermal units is taken from [54]. The data on the hydro units are given in Table A3.

The results comparison listed in Table 5 reveals that ENCSA obtained the best minimum cost, the best standard deviation, and the highest SR (\$2,818,001.70, \$123,993.90, and 66%), while CCSA yields the worst results (\$3,088,459.00, \$153,667.70, and 21%). The best cost and standard deviation from ENCSA are less than those from CCSA by \$270,457.30 and \$29,673.80, respectively, and less than those from MCSA by \$176,590.40 and \$5947.40, respectively. In addition, the SR from ENCSA is also the best value among the three methods, at 66%. As observed in Figure 4, the performance of ENCSA over CCSA and MCSA is outstanding, where the searching speed (change rate of fitness values) of ENCSA is much greater than that of CCSA and MCSA for the first 60 iterations. After the 60th iteration later, the improvement still occurs in ENCSA but there is no significant improvement in CCSA and MCSA. Clearly, the impact of the self-adaptive technique on the performance can lead to a fast convergence to the global optimum and a high-quality solution; in addition, the impact of selection technique-based dominant solutions on the performance can lead to higher SR in ENCSA. Thus, we can conclude that ENCSA is the strongest method among the three compared methods due to the lowest minimum cost, the lowest standard deviation, and the highest SR. The optimal solutions obtained by ENCSA for the two test systems are shown in Tables 4–6.

Table 5. Comparison of obtained results for the IEEE 118 buses system.

	Method					
Parameter	CCSA	MCSA	ENCSA			
P _{ro}	0.9	0.9	0.8			
Min. cost (\$)	3,088,459.0	2,994,592.1	2,818,001.7			
Mean cost (\$)	3,358,689.2	3,216,312.3	2,961,433.3			
Max. cost (\$)	3,665,459.0	3,491,042.1	3,336,941.4			
Std dev. (\$)	153,667.7	129,941.3	123,993.9			
CPU time (s)	278	286	282			
SR	21%	46%	66%			



Figure 4. Fitness function convergence characteristics for the IEEE 118 buses system.

5.4. Discussion of ENCSA and Further Analysis of Results

The proposed method has been developed with the aim of overcoming the disadvantages of CCSA such as the convergence to local optimums or near global optimums and a low SR for complicated systems. In the first improvement of ENCSA, we open the search zone as the current solution and the so-far best solution are close together and avoid adopting large jumping step missing promising zone with high-quality as current solution is far away the so-far best solution. Consequently, the first advantage of the proposed method over CCSA is to choose a suitable search zone for each considered solution. In the second improvement of ENCSA, all old and new solutions are mixed together and identical solutions are abandoned, keeping only one. Finally, the best N_p solutions are retained. Thus, the second advantage of ENCSA over CCSA is to retain N_p different solutions with higher quality than N_p abandoned ones. As to combining the two improvements, firstly, ENCSA can converge to a global optimum with faster speed than CCSA and secondly, ENCSA also gets a higher SR with optimal solutions, satisfying all constraints. However, ENCSA can also cope with several disadvantages that CCSA has not overcome, such as a high number of control parameters and the major effect of parameters on the obtained results. In fact, CCSA has three main parameters consisting of two basic ones of meta-heuristic algorithms-the population size (the number of nests) and the maximum number of iterations—and one advanced control parameter, the new solution update probability in each nest P_{ro} . The selection of the two basic control parameters is based on experience and the trial-error method, with a note that large-scale systems need a higher number of nests and a higher number of iterations. The selection of P_{ro} is not based on experience but should be set to a range from 0.1 to 0.9, and then the best P_{ro} is determined by evaluating the minimum fitness function and standard deviation. On the other hand, ENCSA has one more control parameter than CCSA, which is tol. The selection of tol is not dependent on the scale as well as the complex level of systems but should be set to a range consisting of five values such as 10^{-1} , 10^{-2} , 10^{-3} , 10^{-4} , and 10^{-5} . Consequently, the selection of control parameters of ENCSA should be carefully tuned.

Further analysis of results: Derrac et al. [57] have pointed out that statistical tests should be performed for the obtained results in order to improve performance evaluation of different meta-heuristic algorithms, and the authors have presented the application of testing the sign and Wilcoxon rank-sum for the pairwise comparisons among results obtained by different methods. In Sections 5.2 and 5.3, this paper has compared the results obtained by the proposed method with CCSA and MCSA with respect to the minimum cost, average cost, maximum cost, standard deviation, and SR. The results have indicated that the proposed method obtained a better minimum cost and higher SR than CCSA and MCSA for IEEE 30 and 118 buses power systems but other measures as the average cost, maximum cost, and standard deviation of the proposed method are lower than those of CCSA and MCSA (only for the IEEE 118 buses power system). For further investigation of the proposed method performance, we have chosen the Wilcoxon rank-sum test and Welch's t-test for the analysis of results of the proposed method, CCSA, and MCSA. For implementation of the two tests on the two considered power systems, a level of significance $\alpha = 0.05$ has been considered and obtained *p* values can result in two different cases, in which the first case is that *p* values are less than 0.05 and the second case is that *p* values are equal to or higher than 0.05. In the first case, the proposed method is a significant improvement; otherwise, the proposed method cannot provide solutions with a significant improvement over CCSA and MCSA [57]. The *p* values of Welch's *t*-test and Wilcoxon's rank-sum test are reported in Tables 6 and 7, respectively. As shown in Table 6, the p values for comparison of the proposed method with CCSA and MCSA are approximately 0.3 for IEEE 30 buses hydrothermal power system and less than 0.05 for IEEE 118 buses hydrothermal power system. As observed in Table 7, *p* values are equal to 0.184 and 0.251, respectively, for an IEEE 30 buses hydrothermal power system corresponding to the comparison of the proposed method with CCSA and MCSA, and are 0.0298 and 0.0312, respectively, for IEEE 118 buses hydrothermal power system corresponding to the comparison of the proposed method with CCSA and MCSA. Clearly Welch's *t*-test provides a range of *p* values, while Wilcoxon's rank-sum

test provides a particular value for each comparison. In spite of the difference, such numbers present the same results for evaluation. Both 0.184 and 0.251 are approximately equal to 0.3 and much higher than 0.05, while 0.0298 and 0.0312 are less than 0.05. Consequently, both Welch's *t*-test and Wilcoxon's rank-sum test point out that the proposed method is a significant improvement than CCSA and MCSA for IEEE 118 buses hydrothermal power system; however, the same evaluation is not seen for the IEEE 30 buses hydrothermal power system. The proposed method reached a success rate of 98%, while CCSA and MCSA have obtained success rates of 76% and 91%, respectively; thus, for 50 successful runs, the proposed method has executed only 51 runs while CCSA and MCSA have executed 66 and 55 runs, respectively.

Tested System	Method	Size	Mean	Std.	t	df	p Value
	ASCSA	50	13,808.73	171.314	NA	NA	NA
30 buses	CCSA	50	13,759.82	16.895	2.0093251	0.08428355	≈ 0.3
	MCSA	50	13,783.94	53.707	2.30637854	0.01628009	≈ 0.3
	ASCSA	50	2,961,433.30	123,993.9	NA	NA	NA
118 buses	CCSA	50	3,358,689.20	153,667.7	14.2261863	1.2031E-07	< 0.05
	MCSA	50	3,216,312.30	129,941.3	9.50689037	1.6885E-07	< 0.05

Table 6. The *p* values of Welch's *t*-test for pairwise comparisons.

Table 7. The *p* values of Wilcoxon's rank-sum test for pairwise comparisons.

Tested System	Method	p Value
30 buses	CCSA MCSA	0.184 0.251
118 buses	CCSA MCSA	0.0298 0.0312

The fitness function values obtained by the proposed method, CCSA, and MCSA over 50 successful runs are illustrated in Figures 5 and 6 for the IEEE-30 bus system and the IEEE 118 buses system for further analysis on results. Figure 5 shows a high fluctuation of optimal solutions obtained by the proposed method, while CCSA and MCSA have smaller fluctuations. However, many red points of the proposed method have a lower fitness function than the black points of CCSA and blue points of MCSA, and such red points have approximate fitness values close to the best fitness. Clearly, the obtained results, the *p*-values of Welch's *t*-test, and the *p*-values of Wilcoxon's rank-sum test indicate the highly unstable search ability of the proposed method for the IEEE-30 bus system. In spite of this, the proposed method is still considered more effective than CCSA and MCSA because it finds a better optimal solution and many such better solutions nearby, while CCSA and MCSA cannot reach the zone near the optimal solutions of the proposed method. On the contrary, Figure 6 shows a completely different result since most red points of the proposed method have a much lower fitness function than the black points and blue points from CCSA and MCSA; even the best black point and the best blue point have a better fitness function than a few red points. In addition, the proposed method has a smaller fluctuation than CCSA and MCSA. Clearly, the obtained results, the *p*-values of Welch's t-test, and the p-values of Wilcoxon's rank-sum test can result in the same conclusion that the proposed method outperform CCSA and MCSA in terms of the best optimal solution and the stabilization of the search ability for the IEEE 118 buses system.



Figure 5. Fitness function values obtained by CCSA, MCSA, and the proposed method over 50 runs for the IEEE 30 buses system.



Figure 6. Fitness function values obtained by CCSA, MCSA, and the proposed method over 50 runs for the IEEE 118 buses system.

6. Conclusions

In this paper, an effective novel cuckoo search algorithm (ENCSA) has been proposed to deal with the optimal power flow problems of hydrothermal power systems, considering the constraints in transmission networks. The proposed method is an improved version of the conventional CSA in that it applies two techniques—the self-adaptive technique, which is used for the second step of generating new solutions, and the top solutions-based selection technique to keep the best solutions among all new and old solutions. To verify the performance of ENCSA, two tests cases have been implemented in the IEEE 30 and 118 buses systems. The results from both test cases have proved that ENCSA is a better method compared to CCSA and MCSA in terms of the optimal solution quality, success rate, and convergence speed. The self-adaptive technique can enable ENCSA to overcome the local optimum trap and the selection technique-based dominant solutions can allow ENCSA to reach a better optimal value faster. The results indicate that the proposed ENCSA is efficient at solving the hydrothermal optimal power flow problem.

Author Contributions: Le Van Dai and Thang Trung Nguyen made their contributions to literature search, study design, data analyses, and writing of the whole article. Minh Quan Duong, Bach Hoang Dinh, and Nguyen Vu Quynh performed the experiments.

Conflicts of Interest: The authors declare no conflict of interest.

Nomenclature

a_i, b_i, c_i	Fuel cost coefficients of generating unit <i>i</i>
a_{hj}, b_{hj}, c_{hj}	Water discharge coefficients of hydro plant <i>j</i>
$P_{hj,m}$	Power output of hydro plant <i>j</i> in subinterval <i>m</i>
$P_{hj,max}, P_{hj,min}$	Maximum and minimum power output of hydro plant <i>j</i>
P _{si,m}	Power output of thermal plant <i>j</i> in subinterval <i>m</i>
P _{si,max} , P _{si,min}	Maximum and minimum power output of thermal plant <i>i</i>
$q_{j,m}$	Rate of water flow from hydro plant j in subinterval m
<i>m</i> , <i>M</i>	Index of subinterval and the number of subintervals
t_m	Duration for subinterval <i>m</i>
W_{j}	Volume of water available for generation by hydro unit <i>j</i>
G_{ij}, B_{ij}	Transfer conductance and capacitance between bus i and bus j , respectively
N_b, N_c, N_d	Number of buses, switchable capacitor and load buses
N_g, N_l, N_t	Number of generating units, transmission lines and transformer with tap changing
N_1	Number of thermal generators
N_2	Number of hydro generators
Ng	Number of all generators including thermal and hydro units
P_{di}, Q_{di}	Real and reactive power demands at bus <i>i</i> , respectively
P_{gi}, Q_{gi}	Real and reactive power outputs of generating unit <i>i</i> , respectively
Q _{ci}	Reactive power compensation source at bus <i>i</i>
S_{ij}, S_{ji}	Apparent power flow from bus i to bus j and from bus j to bus i
S_l	Maximum apparent power flow in transmission line <i>l</i>
T_k	Tap-setting of transformer branch k
V_{gi}, V_{li}	Voltage magnitude at generation bus <i>i</i> and load bus <i>i</i> , respectively
V_i, d_i	Voltage magnitude and angle at bus <i>i</i> , respectively
X_{r1}, X_{r2}	Two random solutions withdrawn from the population
rand _d	A random number generated for solution <i>d</i>
P_a	A fraction of alien eggs to be abandoned
X_d	A solution corresponding to nest <i>d</i>
G _{best}	Global best nest
α_0	A positive scaling factor with value in the range [0, 1]
X_{min}, X_{max}	Minimum and maximum values of control variables
Fitness _d	The fitness function of solution <i>d</i>
Fitness _{best}	Fitness function of the best solution
Tol	Predetermined tolerance
D_d	Fitness difference ratio between solution <i>d</i> and the best solution

Appendix A

Table A1. Coefficients of cost function of four thermal units of the IEEE 30 buses system.

Unit No.	<i>a_i</i> (\$/h)	<i>b_i</i> (\$/MWh)	<i>c_i</i> (\$/MW ² h)
1	0	2.00	0.00375
2	0	1.75	0.01750
3	0	1.00	0.06250
4	0	3.25	0.00834

Hydro Plant	a _{hj} (MCF/h)	<i>b_{hj}</i> (MCF/MWh)	c_{hj} (MCF /MW ² h)	<i>W_j</i> (MCF)
1	1.980	0.306	0.000216	200
2	0.936	0.612	0.000360	400

Table A3. The data of hydro units included in the IEEE 118 buses system.

 Table A2. Hydraulic data of hydro units of the IEEE 30 buses system.

Hydro Plant	Bus	a _{hj} (MCF/h)	<i>b_{hj}</i> (MCF/MWh)	c_{hj} (MCF/(MW) ² h)	<i>W_j</i> (MCF)
1	111	1.0836	0.2159	0.000232	400
2	112	0.36	0.07197	$7.73 imes10^{-5}$	120
3	113	1.0836	0.2159	0.000232	400
4	116	0.36	0.07197	$7.73 imes10^{-5}$	120

 Table A4. Optimal solution obtained by ENCSA method for the IEEE 30 buses system.

	Va	lue
Parameter	Subint. 1	Subint. 2
P_{g1} (MW)	153.2844	149.3397
P_{g2} (MW)	43.0415	42.0074
P_{g5} (MW)	19.669	18.0139
P_{g8} (MW)	10	10.0061
P_{g11}^{3} (MW)	24.8623	16.0447
P_{g13} (MW)	40	12
V_{g1} (pu)	1.1	1.0857
V_{g2} (pu)	1.0875	1.0657
V_{g5} (pu)	1.0619	1.042
V_{g8} (pu)	1.0679	1.051
V_{g11} (pu)	1.0962	1.0688
V_{g13} (pu)	1.0998	1.0902
T_{11} (pu)	1.02	1.04
T_{12} (pu)	1.04	0.92
T_{15} (pu)	1.08	1.04
T_{36} (pu)	0.99	1
Q_{c10} (MVAr)	18.9	6.3
Q_{c24} (MVAr)	4.3	4

Table A5. Optimal solutions for subinterval 1 of the IEEE 118 buses system obtained by ENCSA.

Parameter	Value	Parameter	Value	Parameter	Value
P_{g1} (MW)	19.0598	P_{g100} (MW)	235.4283	V _{g76} (PU)	1.0018
P_{g4} (MW)	55.7638	P_{g103} (MW)	29.832	V_{g77} (PU)	1.0186
P_{g6} (MW)	0.5868	P_{g104} (MW)	12.5777	V_{g80} (PU)	1.0244
P_{g8} (MW)	62.9104	P_{g105}^{o} (MW)	0.8445	$V_{g85}^{'}$ (PU)	1.0879
P_{g10} (MW)	385.1619	P_{g107} (MW)	57.3857	V_{g87} (PU)	1.0535
P_{g12} (MW)	77.7162	$P_{g110}^{'}$ (MW)	6.0031	$V_{g89}^{'}$ (PU)	1.0854
P_{g15} (MW)	10.2586	P_{g111} (MW)	72.9236	V_{g90} (PU)	0.9988
P_{g18} (MW)	4.4213	$P_{g112}^{'}$ (MW)	68.6941	V_{g91} (PU)	1.0322
$P_{g19}^{'}$ (MW)	9.2522	$P_{g113}^{'}$ (MW)	79.4957	V_{g92} (PU)	1.0691
P_{g24} (MW)	4.8536	$P_{g116}^{'}$ (MW)	61.6715	V_{g99} (PU)	1.0311
P_{g25} (MW)	186.0854	V_{g1} (PU)	0.9717	V_{g100} (PU)	1.0313
P_{g26} (MW)	268.4305	V_{g4} (PU)	1.0146	V_{g103} (PU)	1.0283
P_{g27} (MW)	22.7964	V_{g6} (PU)	0.9955	V_{g104} (PU)	0.9969
P_{g31} (MW)	4.9791	V_{g8} (PU)	1.0072	V_{g105} (PU)	0.9941
P_{g32} (MW)	23.0057	V_{g10}^{-} (PU)	1.0498	V_{g107} (PU)	1.0015
P_{g34} (MW)	0.9164	V_{g12} (PU)	0.9811	V_{g110} (PU)	1.0588

Parameter	Value	Parameter	Value	Parameter	Value
P_{q36} (MW)	4.7562	V_{g15} (PU)	1.0167	V _{g111} (PU)	1.0884
P_{g40} (MW)	56.9505	V_{g18} (PU)	1.0366	V_{g112} (PU)	1.0684
P_{q42} (MW)	20.769	V_{g19} (PU)	1.0353	V_{g113} (PU)	1.0202
P_{g46} (MW)	16.9152	V_{g24} (PU)	1.0402	V_{g116} (PU)	1.0196
P_{g49} (MW)	196.975	V_{g25} (PU)	1.0208	T_8 (pu)	0.98
P_{g54} (MW)	0.0539	V_{g26}^{*} (PU)	1.0601	T_{32} (pu)	0.9
P_{g55} (MW)	9.424	V_{g27} (PU)	0.9739	T_{36} (pu)	1
P_{g56} (MW)	76.0762	V_{g31} (PU)	1.007	T_{51} (pu)	0.92
P_{g59} (MW)	133.4323	V_{g32} (PU)	0.98	T_{93} (pu)	1
P_{g61} (MW)	142.7216	V_{g34} (PU)	1.0501	T ₉₅ (pu)	1.09
P_{g62} (MW)	4.2606	$V_{g36}^{'}$ (PU)	1.0388	T_{102} (pu)	1.05
P_{g65} (MW)	338.6671	V_{g40} (PU)	1.0447	T_{107} (pu)	1.02
P_{g66} (MW)	332.8104	V_{g42} (PU)	1.0837	T_{127} (pu)	0.97
P_{g69} (MW)	434.6983	V_{g46} (PU)	1.0036	Q_{c5} (MVAr)	-33.3
P_{g70} (MW)	1.1097	$V_{g49}^{'}$ (PU)	1.018	Q_{c34} (MVAr)	3.4
P_{g72} (MW)	0.1819	V_{g54} (PU)	1.0582	Q_{c37} (MVAr)	-18.5
P_{g73} (MW)	0.3883	$V_{g55}^{'}$ (PU)	1.0561	Q_{c44} (MVAr)	7
P_{g74} (MW)	21.8734	V_{g56} (PU)	1.0555	Q_{c45} (MVAr)	4.2
P_{g76} (MW)	2.0134	V_{g59} (PU)	1.0069	Q_{c46} (MVAr)	3.7
P_{g77} (MW)	61.773	V_{g61} (PU)	1.0225	Q_{c48} (MVAr)	1.9
P_{g80} (MW)	406.4545	$V_{g62}^{'}$ (PU)	1.0384	Q_{c74} (MVAr)	0.7
P_{g85} (MW)	22.9793	V_{g65} (PU)	1.0196	Q_{c79} (MVAr)	18.5
P_{g87} (MW)	4.1302	$V_{g66}^{'}$ (PU)	0.9934	Q_{c82} (MVAr)	0
$P_{g89}^{'}$ (MW)	164.3211	$V_{g69}^{'}$ (PU)	0.994	Q_{c83} (MVAr)	0.2
P_{g90} (MW)	47.9289	V_{g70} (PU)	1.0475	Q_{c105} (MVAr)	20
$P_{g91}^{'}$ (MW)	27.7547	V_{g72} (PU)	1.0438	<i>Q</i> _{c107} (MVAr)	1.7
P_{g92} (MW)	32.9663	V_{g73} (PU)	1.0643	Q_{c110} (MVAr)	1
$P_{g99}^{'}$ (MW)	15.4033	V_{g74} (PU)	1.0157	-	

Table A5. Cont.

T-1-1- AC O		aultin tamaal 2 af the	IEEE 110 houses		ENICCA
lable Ab. U	ptimal solutions for	subinterval 2 of the	e IEEE 118 -Duses s	system obtained b	Y EINCSA.

Parameter	Value	Parameter	Value	Parameter	Value
P_{g1} (MW)	8.5778	P_{g100} (MW)	164.7772	V _{g76} (PU)	1.0114
P_{q4} (MW)	5.5039	P_{g103} (MW)	24.7425	V_{g77} (PU)	0.9729
P_{g6} (MW)	97.5555	P_{g104} (MW)	3.1914	$V_{g80}^{'}$ (PU)	0.9698
P_{g8} (MW)	31.8538	P_{g105} (MW)	2.1724	V_{g85} (PU)	0.9591
P_{g10} (MW)	278.4146	P_{g107} (MW)	68.9825	V_{g87} (PU)	0.9531
P_{g12} (MW)	57.9114	P_{g110} (MW)	99.9985	V_{g89} (PU)	0.9666
$P_{g15}^{'}$ (MW)	4.6559	P_{g111} (MW)	38.254	$V_{g90}^{'}$ (PU)	1.008
P_{g18} (MW)	16.1638	$P_{g112}^{'}$ (MW)	17.6654	V_{g91} (PU)	1.0387
P_{g19} (MW)	0.6935	P_{g113} (MW)	1.5754	V_{g92} (PU)	0.9926
P_{g24} (MW)	7.3221	$P_{g116}^{'}$ (MW)	54.8051	V_{g99} (PU)	1.0387
P_{g25} (MW)	125.5236	V_{g1} (PU)	0.9559	V_{g100}^{-} (PU)	1.004
P_{g26} (MW)	262.3018	V_{g4} (PU)	1.0163	V_{g103} (PU)	0.9808
P_{g27} (MW)	4.2622	V_{g6} (PU)	0.9937	V_{g104} (PU)	0.9744
P_{g31} (MW)	1.9636	V_{g8} (PU)	1.0183	V_{g105} (PU)	0.9894
P_{g32} (MW)	53.1329	$V_{g10}^{'}$ (PU)	0.9984	V_{g107} (PU)	1.0007
P_{g34} (MW)	0.763	V_{g12} (PU)	0.9844	V_{g110} (PU)	1.011
P_{g36} (MW)	0.0233	V_{g15} (PU)	1.0946	V_{g111} (PU)	1.0458
P_{g40} (MW)	39.9631	V_{g18} (PU)	1.0531	V_{g112} (PU)	0.952
P_{g42} (MW)	9.4247	V_{g19} (PU)	1.0939	V_{g113} (PU)	1.0726
P_{g46} (MW)	15.8308	V_{g24} (PU)	0.9841	V_{g116} (PU)	1.0523
P_{g49} (MW)	81.5138	V_{g25} (PU)	1.0359	\overline{T}_8 (pu)	0.95
$\bar{P_{g54}}$ (MW)	0.217	V_{g26}^{-} (PU)	0.9543	T ₃₂ (pu)	0.94
P_{g55} (MW)	11.059	V_{g27} (PU)	1.0132	T ₃₆ (pu)	0.99

Parameter	Value	Parameter	Value	Parameter	Value
P_{g56} (MW)	0	V _{g31} (PU)	1.0137	T ₅₁ (pu)	1.01
P_{g59} (MW)	121.5805	V_{g32} (PU)	1.0459	T_{93} (pu)	1.08
P_{g61} (MW)	124.1151	V_{g34} (PU)	1.0788	T_{95} (pu)	1.08
P_{g62} (MW)	0.8983	V_{g36} (PU)	1.0677	T ₁₀₂ (pu)	0.98
P_{g65} (MW)	59.4265	V_{g40} (PU)	1.0986	T_{107} (pu)	1.06
P_{g66} (MW)	285.8251	V_{g42} (PU)	1.0881	T ₁₂₇ (pu)	1.08
P_{g69} (MW)	406.1577	V_{g46} (PU)	1.0272	Q_{c5} (MVAr)	-40
P_{g70} (MW)	1.5995	V_{g49} (PU)	1.0583	Q_{c34} (MVAr)	11.3
P_{g72} (MW)	0.2329	V_{g54} (PU)	1.0871	Q_{c37} (MVAr)	-22
P_{g73} (MW)	3.7515	V_{g55} (PU)	1.087	Q_{c44} (MVAr)	0
P_{g74} (MW)	99.9542	V_{g56} (PU)	1.0808	Q_{c45} (MVAr)	8.7
P_{g76} (MW)	1.9594	V_{g59} (PU)	1.0141	Q_{c46} (MVAr)	9.3
P_{877} (MW)	8.1114	V_{g61} (PU)	0.9962	Q_{c48} (MVAr)	0.2
P_{g80} (MW)	17.8145	V_{g62} (PU)	0.9999	Q_{c74} (MVAr)	9.4
P_{g85} (MW)	4.3697	V_{g65} (PU)	1.0195	<i>Q</i> _{<i>c</i>79} (MVAr)	2.1
P_{g87} (MW)	5.0134	V_{g66} (PU)	1.0264	Q_{c82} (MVAr)	7.6
$P_{g89}^{'}$ (MW)	316.5723	$V_{g69}^{'}$ (PU)	0.9637	Q_{c83} (MVAr)	9.5
P_{g90} (MW)	1.1845	V_{g70} (PU)	1.0143	Q_{c105} (MVAr)	19.3
P_{g91} (MW)	1.5896	V_{g72} (PU)	0.95	Q_{c107} (MVAr)	5.3
$P_{g92}^{'}$ (MW)	0.6171	V_{g73} (PU)	0.95	Q_{c110} (MVAr)	1.4
$P_{g99}^{'}$ (MW)	0.7622	$V_{g74}^{'}$ (PU)	1.0085	-	

Table A6. Cont.

References

- 1. El-Hawary, M.E.; Landrigan, J.K. Optimum operation of fixed-head hydro-thermal electric power systems: Powell's Hybrid Method Versus Newton-Raphson Method. *IEEE Trans. Power Appar. Syst.* **1982**, *PAS-101*, 547–554.
- 2. Wood, A.; Wollenberg, B. Power Generation, Operation and Control; Wiley: New York, NY, USA, 1996.
- 3. Zaghlool, M.F.; Trutt, F.C. Efficient methods for optimal scheduling of fixed head hydrothermal power systems. *IEEE Trans. Power Syst.* **1988**, *3*, 24–30. [CrossRef]
- 4. Rashid, A.H.A.; Nor, K.M. An efficient method for optimal scheduling of fixed head hydro and thermal plants. *IEEE Trans Power Syst.* **1991**, *6*, 632–636. [CrossRef]
- 5. Salam, M.S.; Nor, K.M.; Hamdam, A.R. Hydrothermal scheduling based Lagrangian relaxation approach to hydrothermal coordination. *IEEE Trans. Power Syst.* **1998**, *13*, 226–235. [CrossRef]
- 6. Basu, M. Hopfield neural networks for optimal scheduling of fixed head hydrothermal power systems. *Electr. Power Syst.* 2003, 64, 11–15. [CrossRef]
- 7. Sharma, A.K. Short Term Hydrothermal Scheduling Using Evolutionary Programming. Master's Thesis, Thapar University, Patiala, India, 2009.
- 8. Basu, M. Artificial immune system for fixed head hydrothermal power system. *Energy* **2011**, *36*, 606–612. [CrossRef]
- Farhat, I.A.; El-Hawary, M.E. Fixed-head hydro-thermal scheduling using a modified bacterial foraging algorithm. In Proceedings of the 2010 IEEE Electric Power and Energy Conference (EPEC), Halifax, NS, Canada, 25–27 August 2010; pp. 1–6. [CrossRef]
- 10. Sasikala, J.; Ramaswamy, M. Optimal gamma based fixed head hydrothermal scheduling using genetic algorithm. *Expert Syst. Appl.* **2010**, *37*, 3352–3357.
- Kumar, B.R.; Murali, M.; Kumari, M.S.; Sydulu, M. Short-range Fixed head Hydrothermal Scheduling using Fast Genetic Algorithm. In Proceedings of the 2012 7th IEEE Conference on Industrial Electronics and Applications (ICIEA), Singapore, 18–20 July 2012; pp. 1313–1318.
- 12. Naranga, N.; Dhillonb, J.S.; Kothari, D.P. Scheduling short-term hydrothermal generation using predator prey optimization technique. *Appl. Soft Comput.* **2014**, *21*, 298–308. [CrossRef]
- 13. Dommel, H.W.; Tinny, W.F. Optimal power flow solution. *IEEE Trans. Power Appar. Syst.* **1968**, *PAS-87*, 1866–1876. [CrossRef]

- 14. Stott, B.; Alsac, O.; Monticelli, A.J. Security analysis and optimization. *Proc. IEEE* **1987**, 75, 1623–1644. [CrossRef]
- 15. Momoh, J.A.; Koessler, R.J.; Bond, M.S.; Stott, B.; Sun, D.; Papalexopoulos, A.; Ristanovic, P. Challenges to optimal power flow. *IEEE Trans. Power Syst.* **1997**, *12*, 444–447. [CrossRef]
- 16. Cain, M.B.; O'Neill, R.P.; Castillo, A. *History of Optimal Power Flow and Formulations*; FERC Staff Technical Paper; Federal Energy Regulatory Commission: Washington, DC, USA, 2012.
- 17. Thukaram, D.; Parhasarathy, K.; Khincha, H.P.; Narendranath, U.; Bansilal, A. Voltage stability improvement: Case studies if Indian power networks. *Electr. Power Syst. Res.* **1998**, *44*, 35–44. [CrossRef]
- 18. Yesuratnam, G.; Thukaram, D. Congestion management in open access based on relative electrical distances using Voltage stability criteria. *Electr. Power Syst. Res.* **2006**, 77, 1608–1618. [CrossRef]
- 19. Nagendra, P.; Dey, S.H.n.; Datta, T.; Paul, S. Voltage stability assessment of a power system incorporating FACTS controllers using unique network equivalent. *Ain Shams Eng. J.* **2014**, *5*, 103–111.
- 20. Chen, G.; Lu, Z.; Zhang, Z. Improved Krill Herd Algorithm with Novel Constraint Handling Method for Solving Optimal Power Flow Problems. *Energies* **2018**, *11*, 76. [CrossRef]
- 21. Martinez, J.L.; Ramous, A.; Exposito, G.; Quintana, V. Transmission loss reduction by Interior point methods: Implementation issues and practical experience. *Proc. IEE Gener. Transm. Distrib.* **2005**, *152*, 90–98. [CrossRef]
- 22. Torres, G.L.; Quintana, V.H. An interior point method for non-linear optimal power flow using Voltage rectangular coordinates. *IEEE Trans. Power Syst.* **1998**, *13*, 1211–1218. [CrossRef]
- 23. Torres, G.L.; Quintana, V.H. Optimal power flow by a non-linear complementarity method. *IEEE Trans. Power Syst.* **2000**, *15*, 1028–1033. [CrossRef]
- 24. Oliveira, E.J.; Oliveira, L.W.; Pereira, J.L.R.; Honório, L.M.; Junior, I.C.S.; Marcato, A.L.M. An optimal power flow based on safety barrier interior point method. *Electr. Power Energy Syst.* **2015**, *64*, 977–985. [CrossRef]
- 25. Deb, K. *Multi-Objective Optimization Using Evolutionary Algorithms*; John Wiley and Sons, Inc.: New York, NY, USA, 2001.
- 26. Osman, M.S.; Abo-Sinna, M.A.; Mousa, A.A. A solution to the optimal power flow using genetic algorithm. *Appl. Math. Comput.* **2004**, 155, 391–405. [CrossRef]
- 27. Yuryevich, J. evolutionary programming based optimal power flow algorithm. *IEEE Trans. Power Syst.* **1999**, 14, 1245–1250. [CrossRef]
- 28. Abido, M.A. Optimal power flow using particle swarm optimization. *Int. J. Electr. Power Energy Syst.* 2002, 24, 563–571. [CrossRef]
- 29. El Ela, A.A.A.; Abido, M.A.; Spea, S.R. Optimal power flow using differential evolution algorithm. *Electr. Power Syst. Res.* **2010**, *80*, 878–885. [CrossRef]
- 30. Abido, M.A. Optimal power flow using tabu search algorithm. *Electr. Power Compon. Syst.* **2002**, *30*, 469–483. [CrossRef]
- 31. Bhattacharya, A.; Chattopadhyay, P.K. Application of biogeography-based optimisation to solve different optimal power flow problems. *IET Gener. Transm. Distrib.* **2011**, *5*, 70–80. [CrossRef]
- 32. Roa-Sepulveda, C.A.; Pavez-Lazo, B.J. A solution to the optimal power flow using simulated annealing. *Int. J. Electr. Power Energy Syst.* 2003, 25, 47–57. [CrossRef]
- Vaisakh, K.; Srinivas, L.R.; Meah, K. Genetic eVolving ant direction particle swarm optimization algorithm for optimal power flow with non-smooth cost functions and statistical analysis. *Appl. Soft Comput.* 2013, 13, 4579–4593. [CrossRef]
- 34. Niknam, T.; Narimani, M.R.; Abarghooee, R.A. A new hybrid algorithm for optimal power flow considering prohibited zones and valve point effect. *Energy Convers. Manag.* **2012**, *58*, 197–206. [CrossRef]
- 35. Li, Y.Z.; Li, M.S.; Wu, Q.H. Energy saving dispatch with complex constraints: Prohibited zones, valve point effect and carbon tax. *Electr. Power Energy Syst.* **2014**, *63*, 657–666. [CrossRef]
- 36. Bouchekaraa, H.R.E.H.; Abido, M.A.; Boucherma, M. Optimal power flow using teaching-learning-based optimization technique. *Electr. Power Syst. Res.* **2014**, *114*, 49–59. [CrossRef]
- Ghasemi, M.; Ghavidel, S.; Gitizadeh, M.; Akbari, E. An improved teaching–learning-based optimization algorithm using Lévy mutation strategy for nonsmooth optimal power flow. *Electr. Power Energy Syst.* 2015, 65, 375–384. [CrossRef]
- 38. Sayah, S.; Zehar, K. Modified differential evolution algorithm for optimal power flow with non-smooth cost functions. *Energy Convers. Manag.* **2008**, *49*, 3036–3042. [CrossRef]

- 39. Amjady, N.; Sharifzadeh, H. Security constrained optimal power flow considering detailed generator model by a new robust differential evolution algorithm. *Electr. Power Syst. Res.* **2011**, *81*, 740–749. [CrossRef]
- Tan, Y.; Li, C.; Cao, Y.; Lee, K.Y.; Li, L.; Tang, S.; Zhou, L. Improved group search optimization method for optimal power flow problem considering valve-point loading effects. *Neurocomputing* 2015, 148, 229–239. [CrossRef]
- 41. Bakirtzis, A.G.; Biskas, P.N.; Zoumas, C.E.; Petridis, V. Optimal power flow by enhanced genetic algorithm. *IEEE Trans. Power Syst.* **2002**, *17*, 229–236. [CrossRef]
- 42. Reddy, S.S.; Bijwe, P.R.; Abhyankar, A.R. Faster evolutionary algorithm based optimal power flow using incremental variables. *Electr. Power Energy Syst.* **2014**, *54*, 198–210. [CrossRef]
- 43. Alsac, O.; Scott, B. Optimal power flow with steady state security. *IEEE Trans. Power Appar. Syst.* **1974**, 93, 745–751. [CrossRef]
- 44. Lai, L.L.; Ma, J.T.; Yokoyama, R.; Zhao, M. Improved genetic algorithms for optimal power flow under both normal and contingent operation states. *Electr. Power Energy Syst.* **1997**, *19*, 287–292. [CrossRef]
- 45. Sivasubramani, S.; Swarup, K.S. Multi-agent based differential evolution approach to optimal power flow. *Appl. Soft Comput.* **2012**, *12*, 735–740. [CrossRef]
- 46. Soliman, A.; Mantawy, A.H. *Modern Optimizati on Techniques with Applications in Electric Power Systems;* Springer: New York, NY, USA, 2010.
- 47. Elsaiah, S.; Cai, N.; Benidris, M.; Mitra, J. A Fast Economic Power Dispatch Method for Power System Planning Studies. *IET Gener. Transm. Distrib.* **2015**, *9*, 417–426. [CrossRef]
- 48. El-Hawary, M.E.; Tsang, D.H. The Hydrothermal Optimal Load Flow, A Practical Formulation and Solution Techniques Using Newton's Approach. *IEEE Trans. Power Syst.* **1986**, *1*, 157–166. [CrossRef]
- 49. Habibollahzadeh, H.; Semlyen, G.X.L.A. Hydrothermal optimal power flow based on a combined linear and nonlinear programming methodology. *IEEE Trans. Power Syst.* **1989**, *4*, 530–537. [CrossRef]
- 50. Angelidis, G. Short-term Optimal Hydrothermal Scheduling Problem Considering Power Flow Constraint. *Can. J. Elect. Comp. Eng.* **1994**, *19*, 81–86. [CrossRef]
- 51. Wei, H.; Sasaki, H.; Kubokawa, J. Interior point method for hydro-thermaloptimal power flow. In Proceedings of the 1995 International Conference on Energy Management and Power Delivery (EMPD '95), Singapore, 21–23 November 1995; Volume 2, pp. 607–612.
- 52. Wei, H.; Sasaki, H.; Kubokawa, J.; Yokoyama, R. Large Scale Hydrothermal Optimal Power Flow Problems Based on Interior Point Nonlinear Programming. *IEEE Trans. Power Syst.* **2002**, *15*, 396–403. [CrossRef]
- Lin, S.; Huang, J.; Zhang, J.; Tang, Q.; Qiu, W. Short-term optimal hydrothermal scheduling with power flow constraint. In Proceedings of the 27th Chinese Control and Decision Conference (2015 CCDC), Qingdao, China, 23–25 May 2015; pp. 1189–1194.
- 54. Nguyen, T.T.; Vo, D.N.; Truong, A.V.; Ho, L.D. Meta-Heuristic Algorithms for Solving Hydrothermal System Scheduling Problem Considering Constraints in Transmission Lines. *Glob. J. Technol. Optim.* **2016**, *7*, 1–6. [CrossRef]
- 55. Yang, X.S.; Deb, S. Cuckoo search via Lévy flights. In Proceedings of the World Congress on Nature & Biologically Inspired Computing (NaBIC 2009), Coimbatore, India, 9–11 December 2009; pp. 210–214.
- 56. Walton, S.; Hassan, O.; Morgan, K.; Brown, M.R. Modified cuckoo search: A new gradient free optimisation algorithm. *Chaos Solut. Fractals* **2011**, *44*, 710–718. [CrossRef]
- 57. Derrac, J.; Molina, G.S.D.; Herrera, F. A practical tutorial on the use of nonparametric statistical tests as a methodology for comparing evolutionary and swarm intelligence algorithms. *Swarm Evolut. Comput.* **2011**, *1*, 3–18. [CrossRef]



© 2018 by the authors. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (http://creativecommons.org/licenses/by/4.0/).