Correction

Correction: Arshad A.; et al. An Analysis of Photo-Voltaic Hosting Capacity in Finnish Low Voltage Distribution Networks. *Energies* 2017, *10*, 1702

Ammar Arshad * , Martin Lindner and Matti Lehtonen

Department of Electrical Engineering and Automation, Aalto University, Maarintie 8, 02150 Espoo, Finland; aalto@mlindner.eu (M.L.); matti.lehtonen@aalto.fi (M.L.)
* Correspondence: ammar.arshad@aalto.fi; Tel.: +358-469-679-949

The authors would like to correct following errors: In Table 6, E7 is to be changed to E4 in the second row, last column. The table is located on Page 9 [1]. The correct expressions are given as:

Table 6. Test Networks' mean *HC*s and their limiting constraints.

Region	MV Drop	Balanced (3-Phase)		Unbalanced (1-Phase)	
		μ_{HC} (%)	Limiting Constraint	μ_{HC} (%)	Limiting Constraint
PR	−5%	279.2	E7	155.9	E7,E4
	0%	198.1	E3,E7	128.9	E4,E7
	5%	117.2	E3	87.7	E3
IN	−5%	273.9	E7	156.3	E4
	0%	233.5	E7	117.4	E4
	5%	154.6	E3,E7	98.2	E3,E4
PU	−5%	246.4	E5,E7	95.9	E4,E6
	0%	239.7	E5,E7	95.4	E6,E4
	5%	242.5	E5,E7	86.8	E3,E6

Moreover, on page 10 the paragraph describing table 6 findings, also requires one line change. The correct expressions are given as "For the IN region, the constraints of E4 (−5% and 0% MV changes) and E3 (+5% MV rise case) were violated." Instead of "For the IN region for all MV values, the same constraints of E3 and E7 were violated as in the balanced feed-in scenario."

The manuscript will be updated, and the original one will remain available on the article webpage.

Reference

1. Arshad, A.; Lindner, M.; Lehtonen, M. An Analysis of Photo-Voltaic Hosting Capacity in Finnish Low Voltage Distribution Networks. *Energies* 2017, *10*, 1702. [CrossRef]