



Article Technical and Economic Assessment of Micro-Cogeneration Systems for Residential Applications

Pavel Atănăsoae

Faculty of Electrical Engineering and Computer Science, Stefan cel Mare University of Suceava, Universitatii 13, 720229 Suceava, Romania; atanasoae@eed.usv.ro

Received: 21 November 2019; Accepted: 1 February 2020; Published: 3 February 2020



Abstract: The benefits of cogeneration or combined heat and power (CHP) of large power systems are well proven. The technical and economic viability of micro-cogeneration systems is discussed in this paper as it compares to the separate production of electricity and heat. A case study for an individual household is also provided to better understand the benefits of small power cogeneration from renewable energy sources. Two micro-CHP systems are considered for analysis: the first with Stirling engine, and the second with Rankine Organic Cycle. The reference scenario is an individual household with a gas boiler and electricity from the public network. The results show that it is possible that the payback period for the micro-CHP from renewable energy sources will fall below the accepted average value (<15 years) without the support schemes. The economic and environmental benefits of small power cogeneration systems compared to the traditional scenario are highlighted.

Keywords: combined heat and power plants; micro-CHP; cost benefit analysis; renewable energy sources; residential applications; investment analysis

1. Introduction

Energy efficiency in buildings is a priority of European energy and climate change policies along with policies regarding the security of energy supply and the fight against energy poverty. In the European Union (EU), the energy consumption of buildings accounts for around 40% of the final energy consumption and is responsible for approximately 36% of all carbon dioxide emissions [1]. Therefore, there is a significant potential to reduce these emissions through actions to increase the energy performance of buildings.

The Romanian housing fund consists of approximately 8.2 million homes, distributed in 5.1 million buildings. In urban areas, 72% of the dwellings are in city blocks, while in rural areas, 94.5% of the dwellings are single-family houses.

In domestic households, biomass and natural gas are the main fuels currently used not only for cooking, but also for heating and hot water. Over 90% of households in rural areas and 15% of those in urban areas use biomass (mainly wood) as their main source of heating. The energy efficiency of biomass use is low due to the conversion systems used (especially traditional stoves).

Currently, in the case of new buildings but also of rehabilitated ones, the most common solution to provide utilities for small consumers is a gas or a biomass boiler and electricity from the public network.

Generally, the use of renewable energy technologies in residential buildings is not yet a common practice due to higher investment costs compared to conventional sources. Increasing the share of energy supplied from renewable energy sources is a priority for the EU. Different support schemes to stimulate the production of renewable energy sources are used by EU countries, especially for electricity. The support schemes can be divided into investment support (capital grants, exemptions,

or reductions in purchases of goods) and operating support (price subsidies, green certificates, auction schemes, and tax exemptions or deductions) [2,3].

The benefits of medium and large combined heat and power (CHP) plants have been widely recognized throughout the world. In recent years, there has been an increase in the number of research and development projects worldwide regarding the use of micro-CHP for small residential and commercial applications.

Currently, there is a great diversity of micro-cogeneration technologies available on the market (e.g., Stirling engine, fuel cells, microturbines, internal combustion engines, Rankine Organic Cycle) that can harness primary energy resources, both conventional and renewable [4–9]. There is also a tendency for more than one primary energy source available to be used on a single site [10–12].

In accordance with Directive 2012/27/EU, "micro-cogeneration unit" means a cogeneration unit with a maximum capacity below 50 kWe, and "small scale cogeneration" means cogeneration units with an installed capacity below 1 MWe [13].

Compared to other fossil fuels, the use of natural gas has a much lower impact on the environment in terms of carbon dioxide emissions. Thus, the further use of natural gas seems to be one of the energy transition solutions to a carbon-free energy generation and should be made with the help of the most energy-efficient technologies [14–17]. However, the energy import dependence due to the utilization of natural gas is not negligible in the case of several EU countries, and the vulnerability of a certain country depends on the diversity of its energy sources.

Biomass is a "local fuel". There is now a great diversity of biomass in agriculture and forestry activities that produce large quantities of solid waste and residues. Significant quantities of wood waste come from timber factories and wood processing factories, such as bark, sawdust, wood chips, boards, and parts. Many of these wastes can be used for consumption in small installations in the form of wood pellets or briquettes. Support for the heating sector is highly diverse with price subsidies, tax exemptions, or investment grants [18]. Local biomass resources can be used with a higher energy efficiency in CHP applications [19].

Organic Rankine Cycle (ORC) is increasingly used in medium- and low-power cogeneration applications [20,21]. ORC technology is similar to the classic Rankine cycle but uses an organic liquid instead of water. This technology allows efficient use of heat sources with low thermal potential, such as biomass, geothermal energy, and solar energy [22–24]. In this case, the heat input to the system can be delivered by several renewable energy sources available locally, e.g., solar energy and biomass [25,26].

The cost of the cogeneration units (the specific investment in EURO/kWe) has a tendency of considerable reduction compared to the values of the past years [27–29].

Active energy consumers, often called "prosumers" (because they both consume and produce electricity) introduce new challenges at the level of the public electricity network. Prosumers are a relatively new concept in the distribution grid, and they are a consequence of increasing the share of renewable energy from decentralized systems (distributed generation). In many countries, there is a simplified procedure for connecting to the public network of low power generation systems. Thus, new business models are appearing that have begun to be exploited on the trading platforms for electricity [30–32].

The energy balancing problem is the main challenge for the effective application of micro-CHP in a residential context. The addition of a heat storage system will increase the flexibility of a micro-cogeneration system [33–35]. The energy demand of residential buildings (heating, cooling, and electricity for lighting and appliances) has great importance in the sizing of cogeneration units [36–38].

The specific cost is considerably higher compared to conventional technologies for separate heat production (biomass boiler or natural gas boiler), which is a great current disadvantage of micro-cogeneration units. The main objective of this paper is the economic assessment of micro-cogeneration units from renewable energy sources under current market conditions. The methodology used is in accordance with the recommendations set out in [39,40]. The case of reference is an individual household with a gas boiler and electricity from the public network.

The paper is organized as follows: Section 2 presents a brief description of micro-cogeneration systems, while Section 3 presents the used methodology. The technical and economic viability of small cogeneration systems is discussed in Sections 4 and 5, comparing to the separate production of electricity and heat. Two micro-cogeneration systems are compared to the reference case: A gas boiler and electricity from the public network. Finally, the conclusions of this paper are summarized in Section 6.

2. Description of Different Micro-Cogeneration Systems

In Romania currently, in the case of new domestic households but also of rehabilitated ones, the most common solution to provide utilities is the gas or the biomass boiler and electricity from a public network (Figure 1).



Figure 1. Separate generation of heat and power (CRS, compression refrigeration system).

In the residential sector, micro-cogeneration can be applied using a variety of prime mover technologies such as microturbines, internal combustion engines, fuel cells, Stirling engines, or Rankine Organic Cycle (ORC). The available local renewable energy sources and the conventional sources can be converted together by Stirling engines and Rankine Organic Cycle. Silicon oil is the organic working fluid. Thus, in the operation of the micro-cogeneration system, the sharing of the use of renewable energy sources can be increased and the sharing of conventional sources can be reduced. Some examples of micro-cogeneration units are presented in Table 1 [7,29].

CHP Technology	Manufacturer	P _e (kW)	P _h (kW)	η _e (%)	η _h (%)	η _{CHP} (%)	C _{CHP}
Stirling	Microgen	1.0	6.0	13.5	81.1	94.6	0.167
Stirling	Infinia	1.0	6.4	12.5	80.0	92.5	0.156
Stirling	Sunmachine	3.0	10.5	20.1	70.5	90.6	0.286
Stirling	Disenco	3.0	12.0	18.4	73.6	92.0	0.250
ORC	Cogen Microsystems	1.0	8.8	10.0	88.0	98.0	0.114
ORC	Energetix	1.0	8.0	10.0	80.0	90.0	0.125
ORC	Otag	2.0	16.0	10.4	83.6	94.0	0.124

Table 1. The technical characteristics of micro-cogeneration units.

Stirling engines use an external heat source to produce power. The mechanical energy is generated due to two different temperature zones in the Stirling engine, in which encased process gas is heated and cooled. The Stirling engine has a very special construction, which is free from bearings, joints, and shafts. Longer operational lifetimes are possible with this technology in comparison to traditional internal combustion engines [41,42].

The ORC operation principle is the same as the conventional Rankine cycle, but in this case, the working fluid is an organic compound of low boiling point instead of water, thus decreasing the temperature needed for evaporation. Its main applications are the generation of electricity from renewable heat sources (geothermal, biomass, and solar) and the heat recovery from industrial processes.

Both technologies are considered with "external combustion". Due to the modular construction, they can use a variety of primary energy sources such as natural gas, heating oil, biomass, solar, geothermal, and waste heat. The combined heat and power generation is shown in Figure 2.



Figure 2. Combined generation of heat and power (ES, electricity storage; HS, heat storage; CRS, compression refrigeration system; ARS, absorption refrigeration system).

Demand for electricity will be ensured by the micro-CHP unit and the public electricity network. The electricity differences between local consumption and production are compensated without technical difficulty from the public electricity network. There is also the possibility of storing the electricity generated in cogeneration to be used according to needs. The heat storage system will be used to compensate for the load variations and for increasing the flexibility of the micro-CHP unit. Cooling requirements will be ensured from the absorption refrigeration system or compression refrigeration system depending on the heat available from the micro-CHP unit.

3. Methodology

Identifying the optimal size of micro-CHP systems and the most appropriate operation strategy to be adopted are essential requirements to maximize the benefits of using this technology. Overestimating the size of a micro-CHP unit decreases its feasibility, while underestimating its size reduces the benefits. Consequently, the energy demand profiles of the residential building are necessary.

3.1. Determination of Energy Consumption Related to the Building's Utilities

3.1.1. Energy Consumption for Heating

The calculation method is based on non-stationary heat transfer through the opaque and transparent construction elements of the building envelope. It takes into account the effect of

the contributions due to human activity and solar radiation on the resulting indoor temperature imposed by the thermal comfort norms.

The heat losses of the building envelope, the need to heat infiltration air, and the heating of ventilation supply air in the room from supply air temperature to indoor temperature are considered. The heat demand of a building during the heating season [43]:

$$Q_h = 0.024 \cdot C \cdot \left(\frac{S_E}{R'_m} + 0.33 \cdot n_a \cdot V \cdot B_{1S}\right) \cdot N_{GZC} \quad (kWh/year)$$
(1)

where:

C is the correction coefficient for the variation in time of indoor and outdoor temperatures (*C* = 0.905); S_E is the total area of the building envelope (m²);

 R'_m is the average corrected thermal resistance of the building envelope (m² °C/W);

 n_a is the ventilation rate (h⁻¹);

V is the heated volume of the building (m^3) ;

 B_{1S} is the correction coefficient of the thermodynamic potential characteristic of the fresh air needed to ensure physiological comfort ($B_{1S} = 1.104$);

 N_{GZC} is the number of heating degree days (HDDs).

The average corrected thermal resistance of the building envelope:

$$R'_{m} = \frac{\sum A_{j}}{\sum (A_{j} \cdot U'_{j})}$$
(2)

where U'_{j} is the corrected thermal transmittance of area Aj (walls, top floor, lower floor, windows, and doors).

The duration of the heating season D_Z (the beginning and end of the heating season) is determined from the verification of the equality condition between the reduced indoor temperature in the heated space $\overline{\theta}_{iR}$ and the external reference temperature characteristic of the heated space $\overline{\theta}_{eR}$:

$$\overline{\theta}_{iR}(D_Z) = \overline{\theta}_{eR}(D_Z) \tag{3}$$

The number of heating degree days of a building is determined according to the normal duration of the heating season D_Z and the climatic conditions characteristic of the area in which the building is located:

$$N_{GZC} = \sum_{k} \left(\overline{\theta}_{iRk} - \overline{\theta}_{eRk} \right) \cdot D_{Zk} \tag{4}$$

The external climatic parameters are used in the form of the monthly averages of the external temperatures and the intensity of the solar radiation. In the thermal balance of the occupied spaces, the heat contributions due to solar radiation and human activity are considered.

3.1.2. Energy Consumption for Cooling

The calculation method is based on the thermal balance of the building. The heat flows through transmission, ventilation, the contribution of the internal heat sources, and the solar radiation are considered. The cooling demand of the building in summer [43]:

$$Q_{c} = \sum_{j} \left[\frac{S_{E}}{R'_{m}} \cdot \left(\overline{\theta}_{i0} - \overline{\theta}_{eRj}\right) + 1.1 \cdot n_{a} \cdot V \cdot \rho_{a} \cdot c_{pa} \cdot \left(\overline{\theta}_{i0} - \overline{\theta}_{ej}\right) \right] \cdot D_{Cj} + a_{S} \cdot S_{loc} \quad (kWh/year)$$
(5)

where:

 $\overline{\theta}_{i0}$ is the indoor temperature of comfort (°C);

 $\overline{\theta}_{ej}$ is the outside temperature (°C); $\overline{\theta}_{eRj}$ is the outside reference temperature of the envelope's elements (°C); D_{Cj} is the cooling time of the building (h); a_s are the releases of heat (W/m²); S_{loc} is the total area of the building's envelope (m²); ρ_a is the air density ($\rho_a = 1.2047$ kg/m³ at 20 °C); c_{pa} is the air specific heat ($c_{pa} = 0.281$ Wh/kg°C at 20 °C).

The duration of the cooling process is determined as a result of the analysis of the variation of the indoor air temperature $\overline{\theta}_a(t)$ in the absence of equipped cooling systems in occupied spaces. The operating time of the cooling system results from the equation:

$$\overline{\theta}_{i0} = \overline{\theta}_a(t) \tag{6}$$

The solar heat contributions are according to the solar radiation level of the locality in which the building is located, the orientation of the receiving surfaces, their coefficients of transmission, absorption and reflection of the solar radiation, as well as the transfer characteristics of these surfaces.

3.1.3. Energy Consumption for Domestic Hot Water

The energy demand to prepare domestic hot water corresponds to the energy needed to heat the hot water required by the consumer at the desired temperature [43]:

$$Q_w = \sum_{i=1}^{n} \rho_w \cdot c_w \cdot V_w \cdot (\theta_{wh} - \theta_{wc}) \quad (kWh/year)$$
(7)

where:

 ρ_w is the water density ($\rho_a = 985.6 \text{ kg/m}^3 \text{ at } 55 \text{ °C}$); c_w is the water specific heat ($c_w = 1.161 \text{ Wh/kg}^\circ\text{C}$ at 55 °C). *V* is the required volume of hot water for the period considered (m³); θ_{wh} is the temperature of hot water (°C); θ_{wc} is the temperature of cold water (°C);

In the total energy consumption for hot water, the heat losses on the distribution pipes also are considered.

3.2. Primary Energy Savings

The comparison between combined production and separate production of heat and electricity is based on the principle of comparing the same types of fuel [39]. Primary Energy Saving (PES) is calculated by the equation:

$$PES = \left(1 - \frac{1}{\frac{\eta_{hCHP}}{\eta_{hRef}} + \frac{\eta_{eCHP}}{p_{loss} \cdot \eta_{eRef}}}\right) \cdot 100 \ (\%)$$
(8)

where:

 η_{hCHP} is the heat efficiency of the cogeneration production; η_{eCHP} is the electrical efficiency of the cogeneration production; η_{hRef} is the efficiency reference value for separate production of heat; η_{eRef} is the efficiency reference value for separate production of electricity; p_{loss} is the correction factor for avoided grid losses.

3.3. Carbon Dioxide Emissions

The carbon dioxide emissions are determined based on the primary energy source by using an appropriate conversion factor (Table 2):

$$E_{CO2} = \sum_{i=1}^{n} Q_{f,i} \cdot f_{CO2,i} \quad (\text{kgCO}_2/\text{year})$$
(9)

where:

 $Q_{f,i}$ is the energy consumption (kWh/year);

 $f_{CO2,i}$ is the carbon dioxide emission factor (kgCO₂/kWh).

Table 2. The carbon dioxide emission factor [43].

The Primary Source of Energy	kgCO ₂ /kWh
Natural gas	0.205
Biomass—wood	0.019
Biomass—sawdust	0.016
Biomass—pellets/briquettes	0.039
Biomass—agricultural waste	0.010
Electricity from the public network	0.299

3.4. The Cost Benefit Analysis

The cost benefit analysis (CBA) contains a set of analytical tools used to assess the financial and economic viability of a proposed investment. The most often used tools are the cash flow, the simple payback period (SPBP), the discounted payback period (DPBP), the net present value (NPV), and the internal rate of return (IRR). The NPV, the IRR, the SPBP, and the DPBP indices are defined by the following expressions [44–46]:

$$NPV = \sum_{t=1}^{N} \frac{C_t}{(1+i)^t} - C_0$$
(10)

$$C_0 - \sum_{t=1}^{N} \frac{C_t}{(1 + IRR)^t} = 0$$
(11)

$$SPBP = \frac{C_0}{C_t} \tag{12}$$

$$DPBP = -\frac{ln(1 - SPBP \cdot i)}{ln(1 - i)}$$
(13)

where:

 C_0 is the initial investment cost (Euro); N is the lifetime of the investment; i is the discount rate; C_t is the yearly revenue (Euro/year).

4. Case Study

For the analysis, a single-family residential building with the following characteristics was considered: the heated surface 263 m²; the heated volume 684 m³; the thermal resistance of the outer walls 2.21 m² °C/W; the thermal resistance of the upper floor 5.11 m² °C/W; the thermal resistance of the lower floor 4.67 m² °C/W; the thermal resistance of the windows and doors 0.77 m² °C/W. The building

was located in the Suceava region (47.642353, 26.229929), Romania, climate zone IV. The annual energy consumption and type of primary source used for each utility are shown in Table 3.

Type of Utility	Primary Source of Energy	Annual Energy Consumption (kWh/year) (kWh/m ² ·year)	
Heating	Natural gas	21,303	81
Hot water	Natural gas	9468	36
Cooling	Electricity from the public network	4208	16
Lighting and appliances	g and appliances Electricity from the public network		12

Table 3. Annual energy consumption for utilities (reference case).

The variation of the monthly consumption of the building's utilities is shown in Figure 3. Because the structure of the on-site energy demand may vary in different moments of the day and seasons of the year, energy storage is required for the optimal operation of micro-cogeneration systems.



Figure 3. The variation of the monthly consumption of the building's utilities.

To ensure the energy demand in the building, two cogeneration plants are compared to the reference case: A gas boiler and electricity from the public network. The tariffs for energy consumed from public networks (taxes included) are shown in Table 4 [47]. The reference values for the separate generation of electricity and heat are presented in Table 5 [48]. Table 6 shows the nominal technical characteristics of the two cogeneration plants considered in the case study.

Table 4. The tariffs for energy consumed from public networks.

Electricity (Euro/kWh)	Natural Gas (Euro/kWh)
0.159	0.035

Table 5. Reference values [48].				
Parameter	U.M.	Natural Gas	Biomass	Solar Energy
The reference electrical efficiency	%	53.00	37.00	30.00
The reference thermal efficiency	%	92.00	86.00	92.00
The factor for avoided grid losses- $0.851 (U < 0.45 kV; on-site)$			on-site)	

U.M.	Stirling Engine CHP	ORC CHP
-	Natural gas	Biomass and Solar energy
kWe	1.0	1.0
kWt	6.0	8.8
%	13.50	10.00
%	81.10	88.00
%	94.60	98.00
	U.M. - kWe kWt % % %	U.M. Stirling Engine CHP - Natural gas kWe 1.0 kWt 6.0 % 13.50 % 81.10 % 94.60

Table 6. Nominal technical characteristics.

Figures 4–9 show the end user behavior and its match with the micro-CHP operating mode for several typical days: maximum winter load, average winter load, and minimum summer load.



Figure 4. Typical maximum winter load profile of the Stirling engine CHP: (a) electricity; (b) heat.



Figure 5. Typical average winter load profile of the Stirling engine CHP: (a) electricity; (b) heat.







Figure 7. Typical maximum winter load profile of the ORC CHP: (a) electricity; (b) heat.



Figure 8. Typical average winter load profile of the ORC CHP: (a) electricity; (b) heat.



Figure 9. Typical minimum summer load profile of the ORC CHP: (a) electricity; (b) heat.

It is observed that the operating mode of the two cogeneration systems is different and depends on the power-to-heat ratio. There is a need for flexibility in the use of the available heat or electricity generated by the micro-CHP unit at a given time. Thus, in winter, excess electricity can be stored in the form of heat and used for heating or domestic hot water. In the summer, excess heat can also be stored and used for cooling. Figures 10 and 11 show how the requirements of utilities in the building were correlated with the cogeneration production of heat and electricity for one year.



Figure 10. Stirling engine CHP.



Figure 11. ORC CHP.

The primary sources used may also cover peak thermal demands when the load provided by the cogeneration system is insufficient. In most cases, because the demands for building utilities (heating, cooling, domestic hot water, and electricity) are not at the same time, energy storage is required. The heat storage system represents a key component for the micro-CHP systems since it permits to store the unused heat during electricity production for a later use. The micro-CHP system can primarily track heat demand by supplying electricity as a byproduct or can track electricity demand to generate electricity and use heat as a byproduct. The heat storage will allow the system to capture heat when not in use and then deliver it when the process requires more heat than the cogeneration unit can offer. Electricity storage is used for the same reasons. Depending on the particulars of household consumptions, the storage systems have been dimensioned according to the maximum duration loads to ensure at least three to four hours thermal load and at least two hours electrical load. Oversize of the storage systems can reduce the profitability of the micro-CHP system.

5. Results and Discussion

In order to analyze the feasibility, the difference of investment costs for a micro-CHP system compared to the reference scenario is taken into account. Due to the low power of the micro-CHP system, there is no major difference in operating costs compared to the reference case. Therefore, in this study, the operating and maintenance costs (O&M) are equivalent to a domestic gas boiler [49]. Also, there are no additional costs to staff for the use of biomass. Material handling is done by the owner of the individual household. Table 7 shows the cost range based on the type of prime mover that drives the CHP system [29,50–54]. The results of the technical and economic calculation are presented in Table 8. The cost of the ORC CHP system also includes the cost of solar panels. Pellets and briquettes are the type of biomass considered in the calculation and the price is 0.025 EUR/kWh. Figures 12 and 13 show the Net Present Value (NPV) in both cases.

Parameter	Investment Costs (EUR/kWe)	*O&M Costs (EUR/year)
Stirling engine micro-CHP	2000-8000	50
ORC micro-CHP	4000-12,000	50

Table 7.	Micro-CHP	costs.
----------	-----------	--------

*O&M are the operating and maintenance costs. **Table 8.** Cost benefit analysis.

Parameter	U.M.	Stirling CHP	ORC CHP
Electric power	kWe	1.0	1.0
Cogeneration investment difference	EUR	3500	8000
Electricity storage investment	EUR	720	720
Heat storage investment	EUR	1250	1250
Cooling investment	EUR	-	2940
Total investment	EUR	5470	12,910
Annual savings	EUR/year	658	1288
The internal rate of return	%	10.35	7.73
The simple payback period	Years	9.71	10.02
Discount rate	%	5.00	5.00
The discounted payback period	Years	13.62	14.25
Reduction of CO_2 emissions	kgCO ₂ /year	1377	8544
-	0 2,5		



Figure 12. Net Present Value (NPV) for the Stirling engine CHP.



Figure 13. Net Present Value (NPV) for the ORC CHP.

The discounted payback period (DPBP) is more reliable than the simple payback period (SPBP) as it accounts for time value of money. The DPBP shows the operating period, at the end of which, through the updated cash flow generated, the investment is fully recovered and there is still the possibility of obtaining a cash flow that corresponds to the discount rate. Mathematically, the DPBP is the operating period after which NPV is null. In this case study, the DPBP is 13.62 years in the Stirling CHP case (Figure 12) and 14.25 years in the ORC CHP case (Figure 13). Figure 14 shows the influence of the specific cost of cogeneration technologies on the SPBP and the DPBP. Figure 15 shows how the price increase of natural gas and electricity affects the DPBP. Increasing the price of natural gas as a result of import dependence has the effect of reducing the profitability of the investment, while increasing the price of electricity has the opposite effect. The profitability of the investment is even greater as the difference between the price of electricity from public network and the price of the fuel used in the micro-CHP plant increases as in the case of biomass.



Figure 14. The payback period (PBP): (**a**) the Stirling engine CHP; (**b**) the ORC CHP (50% share of solar energy).



Figure 15. The payback period (PBP) of the Stirling engine CHP: (**a**) natural gas price increase by 10%; (**b**) electricity price increase by 10%.

Figure 16 shows the influence of the solar energy share on the payback period in the ORC CHP case. Thus, even under the conditions of a higher specific investment cost, it is possible that the payback period for the micro-CHP will fall below the accepted average value (<15 years) [43,46].



Figure 16. The influence of the solar energy share on the PBP in the ORC CHP case: (**a**) the ORC CHP (70% share of solar energy); (**b**) the ORC CHP (90% share of solar energy).

Figure 17 shows the reduction of annual carbon dioxide emissions in both scenarios. Compared to the reference scenario, the annual reduction of CO_2 emissions is 1377 kg CO_2 in Scenario 1 and 8544 kg CO_2 in Scenario 2. Obviously, a higher production of renewable energy sources in Scenario 2 will lead to a greater reduction of CO_2 emissions.



Figure 17. The reduction of annual CO₂ emissions.

Although it is expected that the sharing of renewable energy will increase in the coming decades, the fossil fuels (especially natural gas) and other alternative fuels (biomass, biofuels, LPG, etc.) will continue to play a major role in the transition to new and renewable energy sources. Therefore, it is desirable to make efficient use of these fuels with the most energy efficient technologies and with the least environmental impact.

The compact dimensions and the combination with established technology allow the generation of heat and electricity in the modernization of the households. The storage tank volume is a key parameter to optimize the system performance. However, this volume could be limited because it can slightly affect the economic performance of the system. Therefore, it is necessary to optimize the operation in hybrid mode of the cogeneration system in order to maximize the renewable energy sources used.

The investment return is maximum if the volumes of electricity and heat generated will be consumed almost entirely within the perimeter of the location where the micro-CHP unit is located. The success of implementing a micro-cogeneration system will be based on how well the system economically meets the thermal and electric loads and priorities of the residential building.

The benefits of the cogeneration of large power systems are well proven. In the case of micro-CHP, the still large specific investment represents a barrier to its expansion. The main objective of this paper was the economic assessment of the micro-CHP units under the current market conditions. The correct choice of the micro-CHP system and its matching with the consumption demands of the building shows the profitability of the micro-CHP without support schemes.

6. Conclusions

In this case study, two micro-cogeneration systems were compared to the reference case: the first case (Scenario 1) with the Stirling engine CHP, and the second case (Scenario 2) with the ORC CHP. The case of reference was an individual household with a gas boiler and electricity from the public network.

The results of this study show that the investment in a micro-cogeneration system can be attractive and economic performances can be obtained without subsidies (without government or local support schemes). The profitability of the micro-cogeneration system is even higher as the power and heat ratio provided better matches the daily profiles of electric, thermal, and cooling loads.

The conditions (limitations) of obtaining the results and future directions of the research were highlighted. The results were obtained when the electricity generated by the CHP unit is consumed almost entirely inside the household. Also, the average monthly temperatures were used for estimating energy consumption for heating and air conditioning. The analysis of the dynamic factors that can influence the energy consumption in the building represents future directions of study.

If environmental benefits are considered, support from government and local authorities can increase the attractiveness for such systems and the primary sources of energy near the place of consumption are more efficiently used.

Therefore, the micro-cogeneration from renewable sources can be one way of achieving the objectives regarding the competitiveness, security, and sustainability of the energy supply of the individual residential consumers.

In addition, a further criterion for sustainable energy is that any biomass harvested to make household fuels should be done so on a renewable basis to ease pressure on forests and other natural ecosystems.

From this point of view, micro-cogeneration offers optimal solutions for both fossil and renewable fuels. Thus, in the case of small households, the share of primary energy from classical sources can be gradually reduced and the share of primary energy from renewable energy sources can be increased to ensure utilities in the building. The implementation of a micro-cogeneration project in residential applications must consider all of the aspects related to the location and the operating strategies to ensure the profitability of such an investment.

Funding: This research received no external funding.

Acknowledgments: The author did not receive any funds for covering the costs to publish in open access.

Conflicts of Interest: The author declares no conflicts of interest.

References

- Directive 2018/844/EU of the European Parliament and of the Council of 30 May 2018 amending Directive 2010/31/EU on the Energy Performance of Buildings and Directive 2012/27/EU on Energy Efficiency. Available online: https://eur-lex.europa.eu/legal-content/EN/TXT/?uri=uriserv%3AOJ.L_.2018.156.01.0075.01.ENG (accessed on 30 October 2019).
- C18-SD-63-03 (2018), Council of European Energy Regulators, Status Review of Renewable Support Schemes in Europe for 2016 and 2017, Public Report, 14 December 2018. Available online: https://www.ceer.eu/ documents/104400/-/-/80ff3127-8328-52c3-4d01-0acbdb2d3bed (accessed on 17 December 2019).

- 3. 2015 KPMG International Cooperative, Taxes and Incentives for Renewable Energy, 132663-G, September 2015. Available online: https://assets.kpmg/content/dam/kpmg/pdf/2015/09/taxes-and-incentives-2015-web-v2.pdf (accessed on 17 December 2019).
- 4. Arsalis, A. A comprehensive review of fuel cell-based micro-combined-heat-and-power systems. *Renew. Sustain. Energy Rev.* **2019**, *105*, 391–414. [CrossRef]
- 5. Aki, H.; Wakui, T.; Yokoyama, R. Development of an energy management system for optimal operation of fuel cell based residential energy systems. *Int. J. Hydrogen Energy* **2016**, *41*, 20314–20325. [CrossRef]
- 6. Comodi, G.; Cioccolanti, L.; Renzi, M. Modelling the Italian household sector at the municipal scale: Micro-CHP, renewables and energy efficiency. *Energy* **2014**, *68*, 92–103. [CrossRef]
- 7. Barbieri, E.S.; Spina, P.R.; Venturini, M. Analysis of innovative micro-CHP systems to meet household energy demands. *Appl. Energy* **2012**, *97*, 723–733. [CrossRef]
- 8. Dentice d'Accadia, M.; Sasso, M.; Sibilio, S.; Vanoli, L. Micro-combined heat and power in residential and light commercial applications. *Appl. Therm. Eng.* **2003**, *23*, 1247–1259. [CrossRef]
- 9. Ciampi, G.; Rosato, A.; Scorpio, M.; Sibilio, S. Experimental analysis of a micro-trigeneration system composed of a micro-cogenerator coupled with an electric chiller. *Appl. Therm. Eng.* **2014**, *73*, 1309–1322. [CrossRef]
- Dong, J.; Nie, S.; Huang, H.; Yang, P.; Fu, A.; Lin, J. Research on Economic Operation Strategy of CHP Microgrid Considering Renewable Energy Sources and Integrated Energy Demand Response. *Sustainability* 2019, 11, 4825. [CrossRef]
- 11. Ramli, M.A.M.; Bouchekara, H.R.E.H.; Alghamdi, A.S. Effcient Energy Management in a Microgrid with Intermittent Renewable Energy and Storage Sources. *Sustainability* **2019**, *11*, 3839. [CrossRef]
- 12. Lissén, J.M.S.; Rodríguez, L.R.; Parejo, F.D.; Sánchez de la Flor, F.J. An Economic, Energy, and Environmental Analysis of PV/Micro-CHP Hybrid Systems: A Case Study of a Tertiary Building. *Sustainability* **2018**, *10*, 4082. [CrossRef]
- 13. Directive 2012/27/EU of the European Parliament and of the Council of 25 October 2012 on Energy Efficiency. Available online: https://eur-lex.europa.eu/legal-content/EN/TXT/?uri=celex:32012L0027 (accessed on 30 October 2019).
- 14. Longo, S.; Cellura, M.; Guarino, F.; Brunaccini, G.; Ferraro, M. Life cycle energy and environmental impacts of a solid oxide fuel cell micro-CHP system for residential application. *Sci. Total Environ.* **2019**, *685*, 59–73. [CrossRef]
- 15. Ezeamama, A.A.; Albrecht, E. Micro Combined Heat and Power Systems—Evaluation of a Sample Application. *Environ. Nat. Resour. Res.* **2019**, *9*, 1–8. [CrossRef]
- 16. Vishwanathan, G.; Sculley, J.P.; Fischer, A.; Zhao, J.C. Techno-economic analysis of high-efficiency natural-gas generators for residential combined heat and power. *Appl. Energy* **2018**, 226, 1064–1075. [CrossRef]
- 17. Sansawatt, T.; Whiteford, J.R.G.; Harrison, G.P. Assessing the impact of micro CHP on gas and electricity distribution networks. In Proceedings of the 2009 IEEE 44th International Universities Power Engineering Conference (UPEC), Glasgow, UK, 1–4 September 2009.
- 18. Banja, M.; Sikkema, R.; Jégard, M.; Motola, V.; Dallemand, J.F. Biomass for energy in the EU—The support framework. *Energy Policy* **2019**, *131*, 215–228. [CrossRef]
- 19. Dong, L.; Liu, H.; Riffat, S. Development of small-scale and micro-scale biomass-fuelled CHP systems—A literature review. *Appl. Therm. Eng.* **2009**, *29*, 2119–2126. [CrossRef]
- Santos, M.; André, J.; Francisco, S.; Mendes, R.; Ribeiro, J. Off-design modelling of an organic Rankine cycle micro-CHP: Modular framework, calibration and validation. *Appl. Therm. Eng.* 2018, 137, 848–867. [CrossRef]
- 21. Rahbar, K.; Mahmoud, S.; Al-Dadah, R.K.; Moazami, N.; Mirhadizadeh, S.A. Review of organic Rankine cycle for small-scale applications. *Energy Convers. Manag.* **2017**, *134*, 135–155. [CrossRef]
- 22. Arteconia, A.; Zottoa, L.D.; Tascionia, R.; Cioccolanti, L. Modelling system integration of a micro solar Organic Rankine Cycle plant into a residential building. *Appl. Energy* **2019**, *251*, 113408. [CrossRef]
- 23. Wang, R.; Jiang, L.; Ma, Z.; Gonzalez-Diaz, A.; Wang, Y.; Roskilly, A.P. Comparative Analysis of Small-Scale Organic Rankine Cycle Systems for Solar Energy Utilisation. *Energies* **2019**, *12*, 829. [CrossRef]
- 24. Freeman, J.; Guarracino, I.; Kalogirou, S.A.; Markides, C.N. A small-scale solar organic Rankine cycle combined heat and power system with integrated thermal energy storage. *Appl. Therm. Eng.* **2017**, 127, 1543–1554. [CrossRef]

- 25. Aoun, B. Micro Combined Heat and Power Operating on Renewable Energy for Residential Building. Doctoral Dissertation, École Nationale Supérieure des Mines de Paris, Paris, France, 2008.
- 26. Şoimoşan, T.M.; Moga, L.M.; Danku, G.; Căzilă, A.; Manea, D.L. Assessing the Energy Performance of Solar Thermal Energy for Heat Production in Urban Areas: A Case Study. *Energies* **2019**, *12*, 1088. [CrossRef]
- 27. Garcia-Saez, I.; Méndez, J.; Ortiz, C.; Loncar, D.; Becerra, J.A.; Chacartegui, R. Energy and economic assessment of solar Organic Rankine Cycle for combined heat and power generation in residential applications. *Renew. Energy* **2019**, *140*, 461–476. [CrossRef]
- 28. Staffell, I.; Green, R. The cost of domestic fuel cell micro-CHP systems. *Int. J. Hydrog. Energy* **2013**, *38*, 1088–1102. [CrossRef]
- 29. Six, D.; Vekemans, G.; Dexters, A. Market opportunities for micro-CHP in Flanders (Belgium). In Proceedings of the 2009 IEEE 6th International Conference on the European Energy Market, Leuven, Belgium, 27–29 May 2009.
- 30. Brown, D.; Hall, S.; Davis, M.E. Prosumers in the post subsidy era: An exploration of new prosumer business models in the UK. *Energy Policy* **2019**, *135*, 110984. [CrossRef]
- 31. Carrero, M.M.; Sánchez, I.R.; Paepe, W.D.; Parente, A.; Contino, F. Is There a Future for Small-Scale Cogeneration in Europe? Economic and Policy Analysis of the Internal Combustion Engine, Micro Gas Turbine and Micro Humid Air Turbine Cycles. *Energies* **2019**, *12*, 413. [CrossRef]
- 32. Wang, J.; Xu, Q. Economic Dispatch of CHP System Considering Thermal Load Demand Side Management. In Proceedings of the 2018 IEEE 37th Chinese Control Conference (CCC), Wuhan, China, 25–27 July 2018.
- 33. Li, J.; Wang, X.; Zhang, Z.; Blond, S.L.; Yang, Q.; Zhang, M.; Yuan, W. Analysis of a new design of the hybrid energy storage system used in the residential m-CHP systems. *Appl. Energy* **2017**, *187*, 169–179. [CrossRef]
- 34. Mongibello, L.; Capezzuto, M.; Graditi, G. Technical and cost analyses of two different heat storage systems for residential micro-CHP plants. *Appl. Therm. Eng.* **2014**, *71*, 636–642. [CrossRef]
- 35. Ciampi, G.; Rosato, A.; Scorpio, M.; Sibilio, S. Energy performance of a residential building-integrated micro-cogeneration system upon varying thermal load and control logic. *Int. J. Low Carbon Technol.* **2016**, *11*, 75–88. [CrossRef]
- 36. Amber, K.P.; Day, A.R.; Ratyal, N.I.; Ahmad, R.; Amar, M. The Significance of a Building's Energy Consumption Profiles for the Optimum Sizing of a Combined Heat and Power (CHP) System—A Case Study for a Student Residence Hall. *Sustainability* **2018**, *10*, 2069. [CrossRef]
- 37. Fubara, T.C.; Cecelja, F.; Yang, A. Modelling and selection of micro-CHP systems for domestic energy supply: The dimension of network-wide primary energy consumption. *Appl. Energy* **2014**, *114*, 327–334. [CrossRef]
- Shaneb, O.A.; Coates, G.; Taylor, P.C. Sizing of residential μCHP systems. *Energy Build.* 2011, 43, 1991–2001. [CrossRef]
- Dorer, V.; Weber, A. (EMPA, Swiss Federal Laboratories for Materials Testing and Research), Methodologies for the Performance Assessment of Residential Cogeneration Systems, Annex 42 of the International Energy Agency, Energy Conservation in Buildings and Community Systems Programme, September 2007. Available online: https://www.iea-ebc.org/Data/publications/EBC_Annex_42_STC_PAM.pdf (accessed on 17 December 2019).
- 40. Entchev, E.; Tzscheutschler, P. Integration of Microgeneration and Related Technologies in Building, Published by Technische Universität München, Germany, October 2014, Annex 54 of the International Energy Agency, Energy Conservation in Buildings and Community Systems Programme. Available online: https://www.ieaebc.org/Data/publications/EBC_Annex_54_Micro-Generation_Integration_Final_Report.pdf (accessed on 17 December 2019).
- 41. Badea, N. Design for Micro-Combined Cooling, Heating and Power Systems: Stirling Engines and Renewable Power Systems; Springer London Ltd.: London, UK, 2015.
- 42. Ziębik, A.; Hoinka, K. *Energy Systems of Complex Buildings*; Springer Science & Business Media: Berlin/Heidelberg, Germany, 2013.
- Mc001/2006, Methodology for Calculating the Energy Performance of Buildings (the Order of the Romanian Minister of Transport, Constructions and Tourism no. 157/2007). Available online: https://www.mdrap.ro/en/ constructii/eficienta-energetica-in-cladiri-3200 (accessed on 30 October 2019).
- 44. Short, W.; Packey, D.J.; Holt, T. A Manual for the Economic Evaluation of Energy Efficiency and Renewable Energy Technologies. National Renewable Energy Laboratory of the U.S. Department of Energy, 1995. Available online: https://www.nrel.gov/docs/legosti/old/5173.pdf (accessed on 17 December 2019).

- Owens, G. Best Practices Guide: Economic & Financial Evaluation of Renewable Energy Projects. Center for Environment United States Agency for International Development, 2002. Available online: https: //pdf.usaid.gov/pdf_docs/PNADB613.pdf (accessed on 30 October 2019).
- 46. Sartori, D.; Catalano, G.; Genco, M.; Pancotti, C.; Sirtori, E.; Vignetti, S.; Del Bo, C. Guide to Cost-Benefit Analysis of Investment Projects, Economic Appraisal Tool for Cohesion Policy 2014–2020. European Commission, December 2014. Available online: https://ec.europa.eu/regional_policy/sources/docgener/ studies/pdf/cba_guide.pdf (accessed on 30 October 2019).
- 47. Energy Prices and Costs in Europe. Available online: https://ec.europa.eu/energy/en/data-analysis/marketanalysis (accessed on 30 October 2019).
- 48. Commission Delegated Regulation (EU) 2015/2402 of 12 October 2015 Reviewing Harmonised Efficiency Reference Values for Separate Production of Electricity and Heat in Application of Directive 2012/27/EU. Available online: https://eur-lex.europa.eu/eli/reg_del/2015/2402/oj (accessed on 30 October 2019).
- 49. Kuhn, V.; Klemeš, J.; Bulatov, I. Micro-CHP: Overview of Technologies, Products and Field Test Results. In Proceedings of the Clima 2007 WellBeing Indoors, Helsinki, Finland, 10–14 June 2007.
- 50. Milan, R.R. Application of small and micro cogeneration units. Vojnoteh. Glas. 2018, 66, 431-445.
- 51. Lemmens, S. A Perspective on Costs Estimation Techniques Organic Rankine Cycle Systems. In Proceedings of the 3rd International Seminar on ORC Power Systems, Brussels, Belgium, 12–14 October 2015.
- 52. DeValve, T.; Olsommer, T. Micro-CHP Systems for Residential Applications. United Technologies Research Center, 2006. Available online: https://www.osti.gov/servlets/purl/921640/ (accessed on 30 October 2019).
- Jablko, R.; Saniter, C.; Hanitsch, R.; Holler, S. Technical and Economical Comparison of micro CHP systems. In Proceedings of the 2005 International Conference on Future Power Systems, Amsterdam, The Netherlands, 18 November 2005.
- Ciampi, G.; Rosato, A.; Scorpio, M.; Sibilio, S. Energy and Economic Evaluation of Retrofit Actions on an Existing Historical Building in the South of Italy by Using a Dynamic Simulation Software. *Energy Procedia* 2015, 78, 741–746. [CrossRef]



© 2020 by the author. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (http://creativecommons.org/licenses/by/4.0/).