

System No.	100% planar roof area (m ²)	Average hot water use per day (L)	Tank size suggested by the model (L)	Average annual yield (kL/year)	Average number of days with zero supply (days/year)	Percentage of total demand supplied by tank (%)	Estimated cost (\$/kL)
RRH 1	151.7	53.3	2000	18.0	28.2	92%	12.5
			1000	16.5	54.1	84%	12.3
RRH 2	133.9	122.2	2000	31.6	93.1	71%	7.2
			2000	31.6	93.1	71%	7.2
RRH 3	177.5	233.6	2000	47.1	135.6	55%	4.8
			2500	49.6	127.8	58%	4.8
RRH 4	164.5	69.3	2000	22.4	40.5	88%	10.1
			1500	21.5	51.6	85%	10.0
RRH 5	184.8	159.4	2000	39.7	101.1	68%	5.7
			2500	41.5	91.2	71%	5.7