

System No.	80% planar roof area (m ²)	Average hot water use per day (L)	Tank size suggested by the model (L)	Average annual yield (kL/year)	Average number of days with zero supply (days/year)	Percentage of total demand supplied by tank (%)	Estimated cost (\$/kL)
RRH 1	121.3	53.3	2000	17.7	33.2	90%	12.7
			1500	17.2	42.1	88%	12.5
RRH 2	107.1	122.2	1500	28.0	115.5	63%	7.7
			2000	29.5	106.0	66%	7.7
RRH 3	142.0	233.6	2000	43.0	146.8	50%	5.3
			3000	47.0	134.7	55%	5.2
RRH 4	131.6	69.3	2000	21.9	46.0	86%	10.3
			1500	21.0	57.6	82%	10.3
RRH 5	147.8	159.4	2000	37.4	111.3	64%	6.1
			2000	37.4	111.3	64%	6.1