

System No.	80% planar roof area (m ²)	Average total water use per day (L)	Tank size suggested by the model (L)	Average annual yield (kL/year)	Average number of days with zero supply (days/year)	Percentage of total demand supplied by tank (%)	Estimated cost (\$/kL)
RRH 1	121.3	103.3	2000	28.0	82.4	74%	8.1
			2000	28.0	82.4	74%	8.1
RRH 2	107.1	289.2	2000	39.4	171.9	37%	5.8
			2500	41.2	167.7	39%	5.7
RRH 3	142.0	565.6	2000	52.1	193.2	25%	4.4
			2500	54.5	190.8	26%	4.4
RRH 4	131.6	223.0	2000	40.9	146.7	50%	5.5
			3000	44.7	134.6	55%	5.5
RRH 5	147.8	343.1	2000	48.6	170.8	39%	4.7
			3500	55.4	158.2	44%	4.6