

System No.	Estimated roof catchment area (m ²)	Average total water use per day (L)	Tank size suggested by the model (L)	Average annual yield (kL/year)	Average number of days with zero supply (days/year)	Percentage of total demand supplied by tank (%)	Estimated cost (\$/kL)
RRH 1	138.6	103.3	2000	28.9	75.8	76.3%	7.84
			2000	28.9	75.8	76.3%	7.84
RRH 2	72.2	289.2	2000	29.7	187.1	28.1%	7.63
			1500	28.5	189.6	26.9%	7.57
RRH 3	130.5	565.6	2000	49.4	194.3	23.9%	4.60
			2000	49.4	194.3	23.9%	4.60
RRH 4	94.1	223.0	2000	34.6	162.1	42.5%	6.55
			2500	36.1	157.7	44.3%	6.54
RRH 5	113.8	343.1	2000	42.1	179.6	33.6%	5.39
			2500	44.0	176.0	35.1%	5.37